North Carolina - Department of Environment, Health, and Natural Resources
Division of Environmental Management - Groundwater Section
P.O. Box 29535 - Raleigh, N.C. 27626-0535
Phone (919) 733-3221

FOR OFFICE USE ONLY
QUAD. NO. SERIAL NO.
Lat. Long. RO
Minor Basin
Basin Code
Header Ent. GW-1 Ent.

# WELL CONSTRUCTION RECORD

DRILLING CONTRACTOR: Braswell Well Drilling

STATE WELL CONSTRUCTION PERMIT NUMBER: 205316

DRILLER REGISTRATION NUMBER: 163

1. WELL LOCATION: (Show sketch of the location below)
Nearest Town: Ingalls County: Avery
Hanging Rock
(Road, Community, or Subdivision and Lot No.)

2.

| DEPTH From | DEPTH To | DRILLING LOG Formation Description |
|---|---|---|
| 0 | 29 | dirt |
| 29 | 220 | mica schist |

3. DATE DRILLED 10-15-99 USE OF WELL Residential
4. TOTAL DEPTH 220 ft
5. CUTTINGS COLLECTED YES ☐ NO ☑
6. DOES WELL REPLACE EXISTING WELL? YES ☐ NO ☑
7. STATIC WATER LEVEL Below Top of Casing: _____ FT.
(Use "+" if Above Top of Casing)
8. TOP OF CASING IS 1 FT. Above Land Surface*
* Casing Terminated at/or below land surface is illegal unless a variance is issued in accordance with 15A NCAC 2C .0118
9. YIELD (gpm): 60 METHOD OF TEST Blown
10. WATER ZONES (depth): 194 ft.
11. CHLORINATION: Type chlorine Amount 3 tabs
12. CASING:

| | Depth From | Depth To | Diameter | Wall Thickness or Weight/Ft. | Material |
|---|---|---|---|---|---|
| From | 0 | 34 | 6 5/8 | .188 | galv. |
| From | | | | | |
| From | | | | | |

13. GROUT:

| | Depth From | Depth To | Material | Method |
|---|---|---|---|---|
| From | 0 | 20 | cement | poured |
| From | | | | |

14. SCREEN:

| | Depth From | Depth To | Diameter | Slot Size | Material |
|---|---|---|---|---|---|
| From | | | in. | in. | |
| From | | | in. | in. | |
| From | | | in. | in. | |

15. SAND/GRAVEL PACK:

| | Depth From | Depth To | Size | Material |
|---|---|---|---|---|
| From | | | | |
| From | | | | |

16. REMARKS:

If additional space is needed use back of form

LOCATION SKETCH
(Show direction and distance from at least two State Roads, or other map reference points)

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

SIGNATURE OF CONTRACTOR OR AGENT DATE 10-15-99

Submit original to Division of Environmental Management and copy to well owner.

RECEIVED DEC 20 1999 Groundwater Section Asheville Regional Office

RECEIVED JAN 2000 Groundwater Section Asheville Regional Office

RECEIVED DEM GROUNDWATER SECTION 00 JAN -5 PM 3:26

GW-1 REV. 9/91