

211394  
ATB

WELL CONSTRUCTION RECORD

WELL CONTRACTOR: Braswell Well Drilling  
WELL CONTRACTOR CERTIFICATION #: 2133  
STATE WELL CONSTRUCTION PERMIT#: \_\_\_\_\_

1. WELL USE (Check Applicable Box): Residential  Municipal  Industrial  Agricultural  Monitoring   
Recovery  Heat Pump Water Injection  Other  If Other, List Use: \_\_\_\_\_

2. WELL LOCATION: (Show sketch of the location below)  
Nearest Town: Newland County: Avery  
Hughes Community  
(Road Name and Numbers, Community, or Subdivision and Lot No.)

3. DRILLING LOG

| From | To | DEPTH     |
|------|----|-----------|
| 0    | 20 | dirt      |
| 20   | 80 | Blue Rock |

City or Town \_\_\_\_\_ State \_\_\_\_\_ Zip Code \_\_\_\_\_

4. DATE DRILLED 4-6-00  
5. TOTAL DEPTH 80 ft.  
6. CUTTINGS COLLECTED YES  NO   
7. DOES WELL REPLACE EXISTING WELL? YES  NO   
8. STATIC WATER LEVEL Below Top of Casing: \_\_\_\_\_ FT.  
(Use "\*" If Above Top of Casing)

9. TOP OF CASING IS 1 FT. Above Land Surface\*  
\*Top of casing terminated at/or below land surface requires a variance in accordance with 15A NCAC 2C .0118  
10. YIELD (gpm): 20 METHOD OF TEST Blown  
11. WATER ZONES (depth): 30, 35 ft.

12. CHLORINATION: Type chlorine Amount 3 tabs  
13. CASING:

If additional space is needed use back of form

14. GROUT:

| From | To | Depth | Diameter | Wall Thickness or Weight/Ft. | Material |
|------|----|-------|----------|------------------------------|----------|
| 0    | 25 | 25    | 6 5/8    | 128                          | gravel   |

LOCATION SKETCH  
(Show direction and distance from at least two State Roads, or other map reference points)

15. SCREEN:

| From | To | Depth | Diameter | Slot Size | Material      |
|------|----|-------|----------|-----------|---------------|
| 0    | 20 | 20    |          |           | cement poured |

16. SAND/GRAVEL PACK:

| From  | To    | Depth | Size  | Material |
|-------|-------|-------|-------|----------|
| _____ | _____ | _____ | _____ | _____    |

17. REMARKS: \_\_\_\_\_

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

RECEIVED/DENR  
C.W.D. GROUNDWATER SECTION  
00 JUN - 5 PM 2: 58

FOR OFFICE USE  
Quad No: \_\_\_\_\_  
Serial No: \_\_\_\_\_

RECEIVED  
MAY 29 2000  
Groundwater Section  
Asheville Regional Office

RECEIVED  
Groundwater Section  
Asheville Regional Office

4-6-00  
DATE  
GW-1 REV. 12/99

211394