* PLED CHECK

213800

North Carolina - Department of Environment and Natural Resources - Division of Water Quality - Groundwater Section
1636 Mail Service Center - Raleigh, N.C. 27699-1636-Phone (919) 733-3221

WELL CONSTRUCTION RECORD

WELL CONTRACTOR: Braswell Well Drilling
WELL CONTRACTOR CERTIFICATION #: 2133
STATE WELL CONSTRUCTION PERMIT#:

1. WELL USE (Check Applicable Box): Residential ☑ Municipal ☐ Industrial ☐ Agricultural ☐ Monitoring ☐ Recovery ☐ Heat Pump Water Injection ☐ Other ☐ If Other, List Use:

2. WELL LOCATION: (Show sketch of the location below)
Nearest Town: Newland County: Avery
Millers Gap Hwy.
(Road Name and Numbers, Community, or Subdivision and Lot No.)

3.

DRILLING LOG From	To	DEPTH Formation Description
0	43	dirt
43	140	slate Rock

City or Town State Zip Code

4. DATE DRILLED 5-26-00
5. TOTAL DEPTH 140 ft.
6. CUTTINGS COLLECTED YES ☐ NO ☑
7. DOES WELL REPLACE EXISTING WELL? YES ☐ NO ☑
8. STATIC WATER LEVEL Below Top of Casing: _____ FT. (Use "+" if Above Top of Casing)
9. TOP OF CASING IS 1 FT. Above Land Surface*
*Top of casing terminated at/or below land surface requires a variance in accordance with 15A NCAC 2C .0118
10. YIELD (gpm): 12 METHOD OF TEST Blown
11. WATER ZONES (depth): 80, 110, 120
12. CHLORINATION: Type chlorine Amount 3 tabs.

If additional space is needed use back of form

13. CASING:

	Depth From	To	Ft.	Diameter	Wall Thickness or Weight/Ft.	Material
From	0	48	Ft.	6 5/8	.188	galv.
From			Ft.			
From			Ft.			

LOCATION SKETCH
(Show direction and distance from at least two State Roads, or other map reference points)

14. GROUT:

	Depth From	To	Ft.	Material	Method
From	0	20	Ft.	cement	poured
From			Ft.		

15. SCREEN:

	Depth From	To	Ft	Diameter	in.	Slot Size	in.	Material
From		To	Ft.		in.		in.	
From		To	Ft.		in.		in.	
From		To	Ft.		in.		in.	

16. SAND/GRAVEL PACK:

	Depth From	To	Ft.	Size	Material
From		To	Ft.		
From		To	Ft.		

17. REMARKS:

RECEIVED/DEHR DWQ GROUNDWATER SECTION 00 JUL 12 PM 3:31

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

SIGNATURE OF PERSON CONSTRUCTING THE WELL DATE 5-26-00

Submit original to Division of Water Quality, Groundwater Section within 30 days

FOR OFFICE USE ONLY
Quad No:
Serial No.

RECEIVED JUL 3 2000 Groundwater Section Asheville Regional Office

RECEIVED Groundwater Section Asheville Regional Office

GW-1 REV. 12/99