

229880

WELL CONSTRUCTION RECORD

010157

WELL CONTRACTOR: Dewey Wright Well Pump Co., Inc.
 WELL CONTRACTOR CERTIFICATION #: 2791
 STATE WELL CONSTRUCTION PERMIT#: Albert Slatt

1. WELL USE (Check Applicable Box): Residential Municipal Industrial
 Recovery Heat Pump Water Injection Other If Other, List Use: _____
 Agricultural Monitoring

2. WELL LOCATION: (Show sketch of the location below)
 Nearest Town: LINNVILLE County: AVERY
DEV. RD. THE GLENN OF GRANDFTHR OGG HWY 105
(Road Name and Numbers, Community or State)

3. _____
 4. DATE DRILLED 3/22/2001
 5. TOTAL DEPTH 140
 6. CUTTINGS COLLECTED YES NO
 7. DOES WELL REPLACE EXISTING WELL? YES NO
 8. STATIC WATER LEVEL Below Top of Casing: 40 FT.
(Use "+" if Above Top of Casing)

DRILLING LOG

From	To	DEPTH
0	62	Formation Description
62	70	DIRT/BOULDERS/GRAVI
70	75	GRANITE
75	95	CREVICE
95	100	GRANITE
100	140	CREVICE
		GRANITE

9. TOP OF CASING IS 1 FT. Above Land Surface*
*Top of casing terminated at/or below land surface requires a variance in accordance with 15A NCAC 2C.0118

10. YIELD (gpm): 50 METHOD OF TEST: Air
 11. WATER ZONES (depth): 20 gpm 70-75 30 gpm 95-100
0 gpm 0 gpm

12. CHLORINATION: Type HTH Amount 21

13. CASING:

From	To	Depth	Diameter	Wall Thickness or Weight/Ft.	Material
0	64	Ft.	6 1/4	.188	GALV.
From	To	Ft.			
From	To	Ft.			

14. GROUT:

From	To	Depth	Material	Method
0	20	Ft.	Cement	Gravity Flow
From	To	Ft.		

15. SCREEN:

From	To	Depth	Diameter	Slot Size	Material
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	

16. SAND/GRAVEL PACK:

From	To	Depth	Size	Material
From	To	Ft.		
From	To	Ft.		

7. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Albert L. Slatt

4-18-01

SIGNATURE OF PERSON CONSTRUCTING THE WELL
 Submit original to Division of Water Quality, Groundwater Section within 30 days

DATE

LOCATION SKETCH
 (Show direction and distance from at least two adjacent Roads, or other map reference points)



RECEIVED DENR
 DWD GROUNDWATER SECTION
 01 APR 26 PM 2:22

FOR OFFICE USE ONLY
 Quad No: _____
 Serial No: _____