

255188

**WELL CONSTRUCTION RECORD**

WELL CONTRACTOR: Dewey Wright Well Pump Co., Inc.

020313

WELL CONTRACTOR CERTIFICATION #: 2886

STATE WELL CONSTRUCTION PERMIT#: Leslie Reece

1. WELL USE (Check Applicable Box): Residential  Municipal  Industrial  Agricultural  Monitoring   
 Recovery  Heat Pump Water Injection  Other  If Other, List Use: \_\_\_\_\_

2. WELL LOCATION: (Show sketch of the location below)  
 Nearest Town: LINVILLE County: AVERY  
ROARING CREEK RD OFF OLD 19E OFF SQUIRREL CR.  
(Road Name and Numbers, Community, or Subdivision and Lot No.)

3. DRILLING LOG

From	To	Formation Description
0	75	DIRT MUD
75	93	GRANITE
93	94	SHALE
94	231	GRANITE
231	232	SHALE
232	285	GRANITE

4. DATE DRILLED 6/5/2002

5. TOTAL DEPTH 285

6. CUTTINGS COLLECTED YES  NO

7. DOES WELL REPLACE EXISTING WELL? YES  NO

8. STATIC WATER LEVEL Below Top of Casing: 50 FT.  
(Use "+" if Above Top of Casing)

9. TOP OF CASING IS 1 FT. Above Land Surface\*  
\*Top of casing terminated at/or below land surface requires a variance in accordance with 15A NCAC 2C.0118

10. YIELD (gpm): 3 METHOD OF TEST Air

11. WATER ZONES (depth): 1 gpm 93-94 2 gpm 231-232  
0 gpm 0 gpm

12. CHLORINATION: Type HTH Amount 47

If additional space is needed use back of form

13. CASING:

From	Depth	To	Diameter	Wall Thickness or Weight/Ft.	Material
0		81	6 1/8	.350	PVC
From	To	Ft.			
From	To	Ft.			

14. GROUT:

From	Depth	To	Material	Method
0		20	Cement	Gravity Flow
From	To	Ft.		
From	To	Ft.		

15. SCREEN:

From	Depth	To	Diameter	Slot Size	Material
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	

16. SAND/GRAVEL PACK:

From	Depth	To	Size	Material
From	To	Ft.		
From	To	Ft.		

17. REMARKS:  
 I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

FOR OFFICE USE ONLY

Quad No: \_\_\_\_\_

Serial No: \_\_\_\_\_

Leslie Wayne Reece

SIGNATURE OF PERSON CONSTRUCTING THE WELL  
 Submit original to Division of Water Quality, Groundwater Section within 30 days

6-27-02

DATE

