

# WELL CONSTRUCTION RECORD

269100

North Carolina - Department of Environment and Natural Resources - Division of Water Quality - Groundwater Section

WELL CONTRACTOR (INDIVIDUAL) NAME (print) Kevin Roberson CERTIFICATION # 2590  
 WELL CONTRACTOR COMPANY NAME BRASWELL Well Drilling PHONE # (828) 733-2802  
 STATE WELL CONSTRUCTION PERMIT# \_\_\_\_\_ ASSOCIATED WQ PERMIT# \_\_\_\_\_  
 (if applicable) (if applicable)

1. WELL USE (Check Applicable Box): Residential  Municipal/Public  Industrial  Agricultural   
 Monitoring  Recovery  Heat Pump Water Injection  Other  If Other, List Use \_\_\_\_\_

2. WELL LOCATION:  
 Nearest Town: Fragall's County Quay  
10 Paul Ridge Rd  
 (Street Name, Numbers, Community, Subdivision, Lot No., Zip Code)

Topographic/Land setting  
 Ridge  Slope  Valley  Flat  
 (check appropriate box)  
 Latitude/longitude of well location \_\_\_\_\_

3. \_\_\_\_\_  
 (degrees/minutes/seconds)  
 Latitude/longitude source:  GPS  Topographic map  
 (check box)

DEPTH		DRILLING LOG
From	To	Formation Description
0	90	dirt, mud, gravel
90	140	granite, schist

4. DATE DRILLED 10-7-02  
 5. TOTAL DEPTH: 140 ft.  
 6. DOES WELL REPLACE EXISTING WELL? YES  NO   
 7. STATIC WATER LEVEL Below Top of Casing: 30 FT.  
 (Use "+" if Above Top of Casing)  
 8. TOP OF CASING IS 1 FT. Above Land Surface\*  
 \*Top of casing terminated at/or below land surface requires a variance in accordance with 15A NCAC 2C .0118.  
 9. YIELD (gpm): 50 METHOD OF TEST AR  
 10. WATER ZONES (depth): 100 - 105

LOCATION SKETCH

Show direction and distance in miles from at least two State Roads or County Roads. Include the road numbers and common road names.

RECEIVED PERMIT  
 GWC GROUNDWATER SECTION  
 03 FEB 24 PM 4: 04

11. DISINFECTION: Type chlorine Amount 6oz.  
 12. CASING:  

From	Depth	To	Diameter	or Weight/Ft.	Material
0	98	Ft.	6"Ø	2188	galv.


  

From	Depth	To	Diameter	Slot Size	Material
0	40	Ft.	2"		

  
 13. GROUT: Depth \_\_\_\_\_ Material cement Method poured  
 From 0 To 40 Ft. \_\_\_\_\_  
 From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_  
 14. SCREEN: Depth \_\_\_\_\_ Diameter \_\_\_\_\_ Slot Size \_\_\_\_\_ Material \_\_\_\_\_  
 From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_  
 From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in. \_\_\_\_\_  
 15. SAND/GRAVEL PACK:  
 Depth \_\_\_\_\_ Size \_\_\_\_\_ Material \_\_\_\_\_  
 From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_  
 From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

16. REMARKS: \_\_\_\_\_

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER

 10-7-02  
 SIGNATURE OF PERSON CONSTRUCTING THE WELL DATE

Submit the original to the Division of Water Quality, Groundwater Section, 1636 Mail Service Center - Raleigh, NC  
 27699-1636 Phone No. (919) 733-3221, within 30 days. GW-1 REV. 07/2001

