322287

RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878 050603

1. WELL CONTRACTOR:

STEVE PRICE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607
City or Town State Zip Code

(828) - 264-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)
STATE WELL PERMIT #(if applicable)
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box): Residential Water Supply ☑
DATE DRILLED 1/5/2006
TIME COMPLETED 4:30 AM ☐ PM ☑

3. WELL LOCATION:

CITY: INVERSHIELD COUNTY AVERY

OLD FARM RD. OFF SHAWNEE RD OFF GUALTNE
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 3 36 17805
LONGITUDE 081 85760

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☑ GPS ☐ Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. **TOTAL DEPTH:** 345

b. **DOES WELL REPLACE EXISTING WELL?** YES ☐ NO ☐

c. **WATER LEVEL** Below Top of Casing: 80 FT.
(Use "+" If Above Top of Casing)

d. **TOP OF CASING IS** 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. **YIELD (gpm):** 30 **METHOD OF TEST** Air

f. **DISINFECTION: Type** HTH **Amount** 54

g. **WATER ZONES** (depth):

From 234 To 235 From 330 To 332
From To From To
From To From To

6. CASING:

From	To	Ft.	Diameter	Thickness/Weight	Material
0	90		6 1/8	350	PVC
0	0				

7. GROUT:

From	To	Ft.	Material	Method
0	90		Cement	Gravity Flow

8. SCREEN:

From	To	Ft.	Diameter	Slot Size	Material
			in.	in.	
			in.	in.	
			in.	in.	

9. SAND/GRAVEL PACK:

From	To	Ft.	Size	Material

10. DRILLING LOG

From	To	Formation Description
0	94	SAND DIRT
84	234	GRANITE
234	235	GRANITE
235	330	GRANITE
330	332	QUARTZ
332	345	GRANITE
0	0	

11. REMARKS:

1 GPM 234 - 235 28 GPM 330 - 332
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Price 1-19-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

RECEIVED

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05

Asheville Regional Office