



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

326545

WELL CONTRACTOR CERTIFICATION # 2586

060106

1. WELL CONTRACTOR:

LESLIE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 3/22/2006

TIME COMPLETED 3:00 AM PM

3. WELL LOCATION:

CITY: BANNER ELK COUNTY: AVERY

HICKORY NUT GAP RD. OFF 184 OFF 105

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 36.07239

LONGITUDE 081.54622

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 800

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 310 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 10 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 98

g. WATER ZONES (depth):

From UNKNOWN To From To

From To From To

From To From To

6. CASING:

Depth Diameter Weight Material Thickness/

From 0 To 21 Ft. 6 1/8 350 PVC

From 0 To 0 Ft.

From To Ft.

7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From To Ft.

From To Ft.

8. SCREEN:

Depth Diameter Slot Size Material

From To Ft. in. in.

From To Ft. in. in.

From To Ft. in. in.

9. SAND/GRAVEL PACK:

Depth Size Material

From To Ft.

From To Ft.

From To Ft.

10. DRILLING LOG

From To Formation Description

0 15 DIRT

15 800 GRANITE

11. REMARKS:

10 GPM UNKNOWN - 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C. WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reece 5-10-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

LESLIE REECE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

REC'D BY CENTRAL FILE
MAY 18 06