RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

$273.18

WELL CONTRACTOR CERTIFICATION # 2878

060219

1. WELL CONTRACTOR:

STEVE PRICE
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607
City or Town State Zip Code

(828) - 264-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)
STATE WELL PERMIT #(if applicable)
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box): Residential Water Supply ☐ X
DATE DRILLED 5/8/2006
TIME COMPLETED 3:00 AM ☐ PM ☐X

3. WELL LOCATION:

CITY: LINVILLE COUNTY AVERY

LOT # 8 OFF BLACKBEAR TRAIL OFF HWY 221
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 36.02357
LONGITUDE 081.52838

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☐ GPS ☐X Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

Area code - Phone number

5. WELL DETAILS:

a. TOTAL DEPTH: 200

b. DOES WELL REPLACE EXISTING WELL? YES ☐ NO ☐X

c. WATER LEVEL Below Top of Casing: 40 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 20 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 32

g. WATER ZONES (depth):

From	To	From	To
120	121	187	189

6. CASING:

From	To	Depth Ft.	Diameter	Thickness/ Weight	Material
0	100		6 1/8	350	PVC
0	0				

7. GROUT:

From	To	Depth Ft.	Material	Method
0	20		Cement	Gravity

8. SCREEN:

From	To	Depth Ft.	Diameter in.	Slot Size in.	Material

9. SAND/GRAVEL PACK:

From	To	Depth Ft.	Size	Material

10. DRILLING LOG

From	To	Formation Description
0	94	DIRT
94	120	GRANITE
120	121	GRANITE
121	187	GRANITE
187	189	QUARTZ
189	200	GRANITE

11. REMARKS:

1 GPM 120 - 121 19 GPM 187 - 189
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WIT 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price 5-31-0
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

JUN 16 2006

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-
Rev. 7/05