



RESIDENTIAL WELL CONSTRUCTION RECORD

329408

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878

060257

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2651

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED 5/28/2006

TIME COMPLETED 2:00 AM PM X

3. WELL LOCATION:

CITY: INVERSHIELD COUNTY: AVERY

LOT # 1532 IN GOLF COURSE RD. OFF HWY 105

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 36.06380

LONGITUDE 081.51431

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 305

b. DOES WELL REPLACE EXISTING WELL? YES NO X

c. WATER LEVEL Below Top of Casing: 50 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 12 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 53

g. WATER ZONES (depth):

From 230 To 231 From 270 To 272

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Depth	Diameter	Weight	Material	Thickness/
From <u>0</u> To <u>104</u> Ft.	<u>8 1/4</u>	<u>188</u>	<u>GAIV</u>	
From <u>0</u> To <u>0</u> Ft.				
From _____ To _____ Ft.				

7. GROUT:

Depth	Material	Method
From <u>0</u> To <u>20</u> Ft.	<u>Cement</u>	<u>Gravity Flow</u>
From _____ To _____ Ft.		
From _____ To _____ Ft.		

8. SCREEN:

Depth	Diameter	Slot Size	Material
From _____ To _____ Ft.	_____ in.	_____ in.	
From _____ To _____ Ft.	_____ in.	_____ in.	
From _____ To _____ Ft.	_____ in.	_____ in.	

9. SAND/GRAVEL PACK:

Depth	Size	Material
From _____ To _____ Ft.		
From _____ To _____ Ft.		
From _____ To _____ Ft.		

10. DRILLING LOG

From	To	Formation Description
<u>0</u>	<u>98</u>	<u>MUD</u>
<u>98</u>	<u>230</u>	<u>GRANITE</u>
<u>230</u>	<u>231</u>	<u>QUARTZ</u>
<u>231</u>	<u>270</u>	<u>GRANITE</u>
<u>270</u>	<u>272</u>	<u>QUARTZ</u>
<u>272</u>	<u>305</u>	<u>GRANITE</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

DIV OF WATER QUALITY
JUL 19 2006

11. REMARKS:

2 GPM 230 - 231 10 GPM 270 - 272
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Price 7-11-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL