



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

332477

WELL CONTRACTOR CERTIFICATION # 2878

060485

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE

NC

28607

City or Town

State

Zip Code

(828) - 284-2851

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 8/22/2008

TIME COMPLETED 12:30 AM PM

WELL LOCATION:

CITY: LINVILLE COUNTY: AVERY

VERNA SUE LANE OFF COW CAMP RD. OFF SPA

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 36.03662

LONGITUDE 081.58766

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

WELL DETAILS:

TOTAL DEPTH: 125

DOES WELL REPLACE EXISTING WELL? YES NO

WATER LEVEL Below Top of Casing: 70 FT.
(Use "+" if Above Top of Casing)

TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

YIELD (gpm): 6 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 11

g. WATER ZONES (depth):

From 95 To 98 From _____ To _____

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Depth Diameter Weight Material

From 0 To 90 Ft. 6 1/8 350 PVC

From 0 To 0 Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN:

Depth Diameter Slot Size Material

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth Size Material

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From To Formation Description

0 84 DIRT

84 95 GRANITE

95 98 QUARTZ

98 125 GRANITE

11. REMARKS:

6 GPM 95 - 98 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Price 9-15-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.