



RESIDENTIAL WELL CONSTRUCTION RECORD

332478

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878

080514

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P O BOX 308

BOONE

NC

28607

City or Town

State

Zip Code

(828) - 284-2851

Area code - Phone number

WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 8/24/2008

TIME COMPLETED 10:30 AM PM

WELL LOCATION:

CITY: LINVILLE COUNTY AVERY

LICK LOG RD. OFF SQUIRREL CREEK OFF SPAN

Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other (check appropriate box)

LATITUDE 3 38.03118

May be in degrees, minutes, seconds or in a decimal format

LONGITUDE 081.00048

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

WELL DETAILS:

TOTAL DEPTH: 805

DOES WELL REPLACE EXISTING WELL? YES NO

WATER LEVEL Below Top of Casing: 30 FT. (Use "+" if Above Top of Casing)

TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

YIELD (gpm): 0.5 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 116

g. WATER ZONES (depth):

From 490 To 491 From 570 To 571

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Depth Diameter Weight Material

From 0 To 120 Ft. 6 1/8 350 PVC

From 0 To 0 Ft. _____ _____

From _____ To _____ Ft. _____ _____

7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

8. SCREEN:

Depth Diameter Slot Size Material

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth Size Material

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

10. DRILLING LOG

From To Formation Description

0 114 DIRT MUD

114 490 GRANITE

490 491 QUARTZ

491 570 GRANITE

570 571 QUARTZ

571 806 GRANITE

11. REMARKS:

0.25 GPM 490 - 491 0.25 GPM 570 - 571

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C. WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price 9-15-08

SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 17 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.