



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

334761

WELL CONTRACTOR CERTIFICATION # 2878

060492

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**
BOONE NC 28607

City or Town State Zip Code
(**828**) - **264-2651**
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____
STATE WELL PERMIT #(if applicable) _____
DWQ or OTHER PERMIT #(if applicable) _____
WELL USE (Check Applicable Box): Residential Water Supply
DATE DRILLED **9/21/2006**
TIME COMPLETED **3:30** AM PM

3. WELL LOCATION:

CITY: **BANNER ELK** COUNTY: **AVERY**
DOBBINS RD. OFF 184 OFF 105

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 **38.09285**
LONGITUDE 081.50863

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: **305**
b. DOES WELL REPLACE EXISTING WELL? YES NO
c. WATER LEVEL Below Top of Casing: **30** FT.
(Use "+" if Above Top of Casing)
d. TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118
e. YIELD (gpm): **6** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **48**

g. WATER ZONES (depth):
From **270** To **279** From **284** To **285**
From _____ To _____ From _____ To _____
From _____ To _____ From _____ To _____

6. CASING: Thickness/
Depth Diameter Weight Material
From **0** To **23** Ft. **6 1/8** **.350** **PVC**
From **0** To **0** Ft. _____
From _____ To _____ Ft. _____

7. GROUT: Depth Material Method
From **0** To **20** Ft. **Cement** **Gravity Flow**
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____

8. SCREEN: Depth Diameter Slot Size Material
From _____ To _____ Ft. _____ in. _____ in. _____
From _____ To _____ Ft. _____ in. _____ in. _____
From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK: Depth Size Material
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____

10. DRILLING LOG

From	To	Formation Description
0	18	DIRT
18	278	GRANITE
278	279	GRANITE
279	284	GRANITE
284	285	QUARTZ
285	305	GRANITE

RECEIVED
DIV. OF WATER QUALITY
NOV 16 2006

11. REMARKS:

3 GPM 278 - 279 **3 GPM 284 - 285**
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price **11-14-06**
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.,
1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.