



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

334769

WELL CONTRACTOR CERTIFICATION # 2878

060556

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE NC 28607

City or Town State Zip Code

(**828**) - **264-2651**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED **10/10/2006**

TIME COMPLETED **4:33** AM PM X

3. WELL LOCATION:

CITY: **LINVILLE** COUNTY: **AVERY**

APPLETREE LANE OFF COW CAMP RD. OFF TO

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE **3 36.04276**

LONGITUDE **081.57596**

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topographic map attached to this form if not GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: **205**

b. DOES WELL REPLACE EXISTING WELL? YES NO X

c. WATER LEVEL Below Top of Casing: **80** FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): **8** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **26**

g. WATER ZONES (depth):

From **95** To **98** From **150** To **151**

From **185** To **187** From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Depth Diameter Thickness/Weight Material
From **0** To **56** Ft. **8 1/8** **350** **PVC**

From **0** To **0** Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

Depth Material Method
From **0** To **20** Ft. **Cement** **Gravity Flow**

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN:

Depth Diameter Slot Size Material
From _____ To _____ Ft. _____ in. _____ in.

From _____ To _____ Ft. _____ in. _____ in.

From _____ To _____ Ft. _____ in. _____ in.

9. SAND/GRAVEL PACK:

Depth Size Material
From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From	To	Formation Description
0	50	DIRT
50	95	GRANITE
95	98	GRANITE
98	150	GRANITE
150	151	QUARTZ
151	185	GRANITE
185	187	QUARTZ
187	205	GRANITE

RECEIVED
DIV. OF WATER QUALITY

NOV 16 2006

11. REMARKS:

1 GPM 95 - 98 **2 GPM 150 - 151**
3 GPM 185 - 187 **0 GPM -**
0 GPM - **0 GPM -**

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price
SIGNATURE OF CERTIFIED WELL CONTRACTOR 11/14/06
DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.