



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878

060537

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS **P. O. BOX 308**

BOONE NC 28607

City or Town State Zip Code

(**828**) - **264-2851**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID # (if applicable)

STATE WELL PERMIT # (if applicable)

DWQ or OTHER PERMIT # (if applicable)

WELL USE (Check Applicable Box): Residential Water Supply X

DATE DRILLED **10/25/2008**

TIME COMPLETED **4:00** AM PM X

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **AVERY**

BERRY RD. OFF 105

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other

(check appropriate box)

LATITUDE 3 **36.87741**

LONGITUDE 081.49381

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: **305**

b. DOES WELL REPLACE EXISTING WELL? YES NO X

c. WATER LEVEL Below Top of Casing: **50** FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): **30** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **53**

g. WATER ZONES (depth):

From **81** To **183** From **270** To **272**

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Thickness/
Depth Diameter Weight Material
From **0** To **88** Ft. **6 1/4** **.188** **GALV**

From **0** To **0** Ft. _____ _____

From _____ To _____ Ft. _____ _____

7. GROUT:

Depth Material Method
From **0** To **20** Ft. **Cement** **Gravity Flow**

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

8. SCREEN:

Depth Diameter Slot Size Material
From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth Size Material
From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

From _____ To _____ Ft. _____ _____

10. DRILLING LOG

From	To	Formation Description
0	81	BOULDERS MUD
81	183	GRANITE
183	184	GRANITE
184	270	GRANITE
270	272	QUARTZ
272	305	GRANITE

RECEIVED
DIV. OF WATER QUALITY

DEC 14 2006

11. REMARKS:

1 GPM 81 - 183 20 GPM 270 - 272

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Price

SIGNATURE OF CERTIFIED WELL CONTRACTOR

STEVE PRICE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

DATE

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.