



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878

060618

335984

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28807

City or Town State Zip Code

(**828**) - **264-2651**

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply **X**

DATE DRILLED 10/24/2006

TIME COMPLETED 4:30 AM PM

3. WELL LOCATION:

CITY: LINVILLE COUNTY: AVERY

HICKORY NUT GAP RD. OFF MONTEZUMA RD. 0

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 36.05964

LONGITUDE 081.55245

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 305

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 30 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 3 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 56

g. WATER ZONES (depth):

From 249 To 249 From 276 To 276

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Depth Diameter Weight Material
From 0 To 28 Ft. 6 1/8 350 PVC

From 0 To 0 Ft. _____ _____ _____

From _____ To _____ Ft. _____ _____ _____

7. GROUT:

Depth Material Method
From 0 To 20 Ft. Cement Gravity Flow

From _____ To _____ Ft. _____ _____ _____

From _____ To _____ Ft. _____ _____ _____

8. SCREEN:

Depth Diameter Slot Size Material
From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth Size Material
From _____ To _____ Ft. _____ _____ _____

From _____ To _____ Ft. _____ _____ _____

From _____ To _____ Ft. _____ _____ _____

10. DRILLING LOG

From To Formation Description
0 21 DIRT

21 248 GRANITE

248 249 GRANITE

249 275 GRANITE

275 276 QUARTZ

276 305 GRANITE

RECEIVED
DIV. OF WATER QUALITY

DEC 14 2006

11. REMARKS:

1 GPM 248 - 249 2 GPM 275 - 276

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Price 120606
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.