



# RESIDENTIAL WELL CONSTRUCTION RECORD

337667

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878

060556-2

### 1. WELL CONTRACTOR:

**STEVE PRICE**

Well Contractor (Individual Name)

**DEWEY WRIGHT WELL & PUMP CO., INC.**

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

**BOONE**

**NC**

**28607**

City or Town

State

Zip Code

( 828 ) - 264-2651

Area code - Phone number

### 2. WELL INFORMATION:

SITE WELL ID #(if applicable) \_\_\_\_\_

STATE WELL PERMIT #(if applicable) \_\_\_\_\_

DWQ or OTHER PERMIT #(if applicable) \_\_\_\_\_

WELL USE (Check Applicable Box): Residential Water Supply  X

DATE DRILLED 12/5/2006

TIME COMPLETED 3:00 AM  PM  X

### 3. WELL LOCATION:

CITY: DRILLED DEEPER COUNTY AVERY

APPLETREE LANE COW CAMP RD. OFF TOE RM

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

### TOPOGRAPHIC / LAND SETTING:

Slope  Valley  Flat  Ridge  Other  
(check appropriate box)

LATITUDE 3 36.04276

LONGITUDE 081.57598

Latitude/longitude source:  GPS  Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

May be in degrees, minutes, seconds or in a decimal format

### 5. WELL DETAILS:

a. TOTAL DEPTH: 705

b. DOES WELL REPLACE EXISTING WELL? YES  NO  X

c. WATER LEVEL Below Top of Casing: 80 FT.  
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface\*  
\* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 1 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount \_\_\_\_\_

g. WATER ZONES (depth):

From 500 To 501 From \_\_\_\_\_ To \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

### 6. CASING:

Depth Diameter Thickness/Weight Material

From 0 To 0 Ft. \_\_\_\_\_

From 0 To 0 Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 8. SCREEN:

Depth Diameter Slot Size Material

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in.

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in.

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_ in. \_\_\_\_\_ in.

### 9. SAND/GRAVEL PACK:

Depth Size Material

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

From \_\_\_\_\_ To \_\_\_\_\_ Ft. \_\_\_\_\_

### 10. DRILLING LOG

From To Formation Description

0 705 OLD WELL

0 0 DRILLED DEEPER

705 500 GRANITE

500 501 QUARTZ

501 705 GRANITE

RECEIVED  
DIV. OF WATER QUALITY

JAN 29 2007

### 11. REMARKS:

1 GPM 500 - 501 0 GPM

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price  
SIGNATURE OF CERTIFIED WELL CONTRACTOR 1-29-07 DATE

STEVE PRICE  
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.,  
1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.