



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION #: 2686

325813
060127

1. WELL CONTRACTOR:

LESLIE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2651

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 3/30/2006

TIME COMPLETED 1:00 AM PM

3. WELL LOCATION:

CITY: BANNER ELK COUNTY: AVERY

BARN/ART CENTERS WELL-TOTEM POLES OFF H

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 36.10947

LONGITUDE 091.53982

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 700

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 150 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 6 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 113

g. WATER ZONES (depth):

From 131 To 162 From To

From To From To

From To From To

6. CASING: Thickness/

Depth Diameter Weight Material

From 0 To 21 Ft. 8 1/8 350 PVC

From 0 To 0 Ft.

From To Ft.

7. GROUT: Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From To Ft.

From To Ft.

8. SCREEN: Depth Diameter Slot Size Material

From To Ft. in. in.

From To Ft. in. in.

From To Ft. in. in.

9. SAND/GRAVEL PACK: Depth Size Material

From To Ft.

From To Ft.

From To Ft.

10. DRILLING LOG

From To Formation Description

0 2 DIRT

2 161 GRANITE

161 182 GRANITE

182 700 GRANITE

11. REMARKS:

8 GPM 181 - 182 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie W. Reece 4-19-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

LESLIE REECE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

RECEIVED

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a Rev. 7/05

Asheville Regional Office