



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

30533

WELL CONTRACTOR CERTIFICATION #

2878

060258-2

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)
DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name
P. O. BOX 308

STREET ADDRESS
BOONE NC 28807

City or Town State Zip Code
(828) 284-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____
STATE WELL PERMIT #(if applicable) _____
DWQ or OTHER PERMIT #(if applicable) _____
WELL USE (Check Applicable Box): Residential Water Supply
DATE DRILLED **7/4/2006**
TIME COMPLETED **4:00** AM PM

3. WELL LOCATION:

CITY: **BOONE** COUNTY: **AVERY**
LOT #45 CHESTNUT FALLS OFF PINNACLE RIDG

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE **3 38 12247**
LONGITUDE **081 54403**

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

- a. TOTAL DEPTH: **505**
- b. DOES WELL REPLACE EXISTING WELL? YES NO
- c. WATER LEVEL Below Top of Casing: **80** FT.
(Use "+" if Above Top of Casing)
- d. TOP OF CASING IS **1** FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118
- e. YIELD (gpm): **2** METHOD OF TEST **Air**

f. DISINFECTION: Type **HTH** Amount **88**

g. WATER ZONES (depth):
From **488** To **489** From _____ To _____
From _____ To _____ From _____ To _____
From _____ To _____ From _____ To _____

6. CASING: Thickness/
Depth Diameter Weight Material
From **0** To **30** Ft. **6 1/8** **.350** **PVC**
From **0** To **0** Ft. _____
From _____ To _____ Ft. _____

7. GROUT: Depth Material Method
From **0** To **20** Ft. **Cement** **Gravity Flow**
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____

8. SCREEN: Depth Diameter Slot Size Material
From _____ To _____ Ft. _____ in. _____ in. _____
From _____ To _____ Ft. _____ in. _____ in. _____
From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK: Depth Size Material
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____
From _____ To _____ Ft. _____

10. DRILLING LOG

From	To	Formation Description
0	24	DIRT
24	488	GRANITE
488	489	RED GRANITE
489	505	GRANITE

11. REMARKS:

2 GPM 488 - 489 0 GPM -
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price **8-10-06**
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.