

**SOURCE INFORMATION**  
**GROUND WATER**

Date Form Completed

03/22/07

01-95-168

FWS

Owner Assigned

Source Code **W02** Well Name (If purchase, name of seller) **Well 2**

Code **G**  
G=Ground  
W=Purchase/G  
Y=G w/direct influence  
Z=W w/direct influence

If purchase, seller ID# \_\_\_\_\_ Source Begin Date MM - YY \_\_\_\_\_ Direct Influence Date MM - DD - YY \_\_\_\_\_

Availability **P**  
P=Permanent  
E=Emergency  
S=Seasonal  
I=Interim  
O=Other

Location of well within the system (If purchase, location of master meter)  
**rear of park next to river (to left of well 1)**

Latitude (N) Deg. Min Sec **36-09-15.29** Longitude (W) Deg. Min Sec **81-47-05.29**

How Determined **G**  
G=GPS  
M=Map  
S=Surveyed  
D=Differential GPS

GPS File Name **U071416B-2000**

If purchase, use seller's primary source lat/long MM - DD - YY \_\_\_\_\_  
Vulnerable VOC's  Y  N Assessment Date \_\_\_\_\_

**ENTRY POINT INFORMATION**

Owner Assigned  
Entry Point Code **E02** Entry Point Name **Well 2**

Use Code **C** C=Ground/Permanent D=Ground/non-Permanent  
Availability **P** P=Year-round E=Emergency S=Seasonal I=Interim O=Other  
Entry Point Begin Date MM / YY \_\_\_\_\_ Entry Point End Date MM / YY \_\_\_\_\_

Location:  
Well Site: Owned or controlled? **Y** (Y,N) Control Area (100' radius?) **N** (Y,N) If no, explain: **river and MH's**  
Sources of pollution/distance: **are less than 100' also in flood plain for Watauga River**

Surface water within 200'? **Y** (Y,N) If yes, actual distance **80** If yes, bact. samples collected? \_\_\_\_\_ (Y,N)  
Adequate slope? **Y** (Y,N) Flooding? **Y** (Y,N) Maintenance: **fair**

Well House: Free of stored materials? **Y** (Y,N) Properly drained? **Y** (Y,N) Locked? **Y** (Y,N)  
Condition of house: **good** Type of freeze protection: **electric heat**

Well: Diameter: **6 1/4"** Type: **drilled** **2-7-95** Yield (gpm): **8.5est** Properly sealed? **Y** (Y,N)  
Properly vented? **Y** (Y,N) Casing Depth **46** ft (If unknown, put 'UNK') Well depth: **365** Meter available? **Y** (Y,N)

Concrete slab adequate? **Y** (Y,N) If no, explain: \_\_\_\_\_ Size: **3'r**  
Size of blow-off: **none** Sample tap?: Before treatment? **Y** (Y,N) After Treatment? **Y** (Y,N)

Pumps: Capacity: GPM: **unk** HP: **unk** Pump intake depth: **unk** Auxiliary Power? **N** (Y,N)  
Type pump: **submersible** Height above floor (pump/casing): \_\_\_\_\_ / **4"**

Storage at well site: Elev: \_\_\_\_\_ Hydro: **\$** Ground: **0,150**  
If hydro, air volume control? \_\_\_\_\_ (Y,N) Safety valves: \_\_\_\_\_ (Y,N) Coded? \_\_\_\_\_ (Y,N)  
High service pumps: 1. ? gpm ? hp 2. ? gpm ? hp 3. ? gpm ? hp Auxiliary power? \_\_\_\_\_ (Y,N)

Is water treated? **N** (Y,N) If yes, complete back of form.  
If other wells are treated here, which ones? \_\_\_\_\_ If treated elsewhere, where? \_\_\_\_\_  
If purchase, retreat? \_\_\_\_\_ (Y/N) If yes, complete back of form.