

605

SOURCE INFORMATION GROUND WATER

Date Form Completed

01/27/05

801-95-108

FWS

Owner Assigned

Source Code Well Name (If purchase, name of system)

1BT Well 1

Code G=Ground
W=Purchase/G
G Y=G w/direct influence
Z=W w/direct influence

Availability

P=Permanent I=Interim
E=Emergency O=Other
S=Seasonal

If purchase, seller ID# Source Begin Date Direct Influence Date
MM - YY MM - DD - YY

Location of well within the system (If purchase, location of master meter)

on right side of SR 1620 as you turn off of SR 1613

Latitude (N)

Longitude (W)

How Determined

Deg. Min Sec

Deg. Min Sec

G=GPS
G M=Map
S=Surveyed
D=Differential GPS

36-12-39.04

81-36-18.79

GPS File Name U082213E-2000

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's Y N

Assessment Date

ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code Entry Point Name

1AT

Well 1

Use Code

Availability

Entry Point Begin Date

Entry Point End Date

C=C=Ground/Permanent
D=Ground/non-Permanent

P=P=Year-round S=Seasonal
E=Emergency I=Interim O=Other

MM / YY

MM / YY

Location: on right side of 1620 as you turn off of 1613 (has storage tank with it)

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius?) Y (Y,N) If no, explain:

Sources of pollution/distance: none

Surface water within 200'? Y N If yes, actual distance If yes, bact. samples collected? (Y/N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: excellent

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: excellent Type of freeze protection: elec. heater

Well: Diameter: 6 1/4" Type: drilled 1970 Yield (gpm): 33 Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth unk (If unknown, put 'UNK') ft Well depth: 200' Meter available? Y (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: Size: 3'r

Size of blow-off: 1 1/2" Sample tap?: Before treatment? Y (Y,N) After Treatment? Y (Y,N)

Pumps: Capacity: GPM: 40 HP: 5 Pump intake depth: 127' Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 8"

Storage at well site: Elev: Hydro: 2,000 Ground:

If hydro, air volume control? Y (Y,N) Safety valves: Y (Y,N) Coded? unk (Y,N)

High service pumps: 1. gpm 5 hp 2. gpm 5 hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated at this well? Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.