

040

### SOURCE INFORMATION GROUND WATER

Date Form Completed

01/27/05

01-95-128

FWS

Owner Assigned

Source Code

Well Name (If purchase, name of system)

1BT

Well 1

Code

G=Ground  
W=Purchase/G  
Y=G w/direct influence  
Z=W w/direct influence

G

If purchase, seller ID#

Source Begin Date

MM - YY

Direct Influence Date

MM - DD - YY

Availability

P

P=Permanent  
E=Emergency  
S=Seasonal  
I=Interim  
O=Other

Location of well within the system (If purchase, location of master meter)

across street from lots 56 and 57

Latitude (N)

Deg. Min Sec

36-09-08.93

Longitude (W)

Deg Min Sec

81-37-04.93

How Determined

G=GPS  
M=Map  
S=Surveyed  
D=Differential GPS

G

GPS File Name S050114A-1998

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's

Y  
N

Assessment Date

### ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code

Entry Point Name

1AT

Well 1

Use Code

C=C=Ground/Permanent  
D=D=Ground/non-Permanent

C

Availability

P=P=Year-round  
E=E=Emergency  
S=S=Seasonal  
I=I=Interim  
O=O=Other

P

Entry Point Begin Date

MM / YY

Entry Point End Date

MM / YY

Location: in well house after treatment

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius?) Y (Y,N) If no, explain:

Sources of pollution/distance:

Surface water within 200'? N (Y,N) If yes, actual distance If yes, bact. samples collected? (Y/N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: good

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: very good Type of freeze protection: electric heater

Well: Diameter: 6 1/4" Type: drilled 1972? Yield (gpm): 25 Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth 21 ft (If unknown, put 'UNK') Well depth: 230' Meter available? Y (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: Size: 4'r

Size of blow-off: 2" Sample tap?: Before treatment? Y (Y,N) After Treatment? Y (Y,N)

Pumps: Capacity: GPM: 32 HP: 3 Pump intake depth: 189' Auxiliary Power? na (Y,N)

Type pump: submersible Height above floor (pump/casing): / 6"

Storage at well site: Elev: Hydro: Ground:

If hydro, air volume control? (Y,N) Safety valves: (Y,N) Coded? (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated at this well? Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.