

041

SOURCE INFORMATION GROUND WATER

Date Form Completed

01/27/05

01-95-128
FWS

Owner Assigned

Source Code

Well Name (If purchase, name of system)

2BT

Well 2

Code

G

G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

If purchase, seller ID#

Source Begin Date

Direct Influence Date

MM - YY

MM - DD - YY

Availability

P

P=Permanent
E=Emergency
S=Seasonal
I=Interim
O=Other

Location of well within the system (If purchase, location of master meter)

next to pond

Latitude (N)

Longitude (W)

How Determined

Deg. Min Sec

Deg. Min Sec

G=GPS
M=Map
S=Surveyed
D=Differential GPS

36-09-14.30

81-37-11.50

G

GPS File Name S050114B-1998

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's

Y
N

Assessment Date

ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code

Entry Point Name

2AT

Well 2

Use Code

C=C=Ground/Permanent
D=D=Ground/non-Permanent

Availability

P=P=Year-round
E=E=Emergency
S=Seasonal
I=Interim
O=Other

Entry Point Begin Date

MM / YY

Entry Point End Date

MM / YY

Location: in well house after treatment

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius?) Y (Y,N) If no, explain:

Sources of pollution/distance: pond 100' away

Surface water within 200'? Y^Y_N If yes, actual distance 100 If yes, bact. samples collected? Y (Y/N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: excellent

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: very good Type of freeze protection: electric heater

Well: Diameter: 6 1/4" Type: drilled 1972 Yield (gpm): 18est Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth unk^(If unknown, put 'UNK') ft Well depth: 230' Meter available? Y (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: Size: 3'r

Size of blow-off: 2" Sample tap?: Before treatment? Y (Y,N) After Treatment? Y (Y,N)

Pumps: Capacity: GPM: 23 HP: 3 Pump intake depth: 189' Auxiliary Power? na (Y,N)

Type pump: submersible Height above floor (pump/casing): / 6"

Storage at well site: Elev: Hydro: Ground:

If hydro, air volume control? (Y,N) Safety valves: (Y,N) Coded? (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated at this well? Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.