

046

### SOURCE INFORMATION GROUND WATER

Date Form Completed

12/08/05

PWS  
01-95-145

Owner Assigned

Source Code

Well Name (If purchase, name of seller)

S01

Well 1

Code G=Ground  
W=Purchase/G  
Y=G w/direct influence  
Z=W w/direct influence

G

If purchase, seller ID#

Source Begin Date  
MM - YY

Direct Influence Date  
MM - DD - YY

Availability

P=Permanent  
E=Emergency  
S=Seasonal  
I=Interim  
O=Other

P

Location of well within the system (If purchase, location of master meter)

between cabins 3 and 5

Latitude (N)

Longitude (W)

How Determined

Deg. Min Sec

Deg. Min Sec

G=GPS  
M=Map  
S=Surveyed  
D=Differential GPS

36-12-20.58

81-44-15.34

G

GPS File Name U112816A-2000

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's  Y  
 N

Assessment Date

### ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code

Entry Point Name

100

Well 1

Use Code

Availability

Entry Point Begin Date

Entry Point End Date

C=Ground/Permanent  
D=Ground/non-Permanent

P=Year-round S=Seasonal  
E=Emergency I=Interim O=Other

MM / YY

MM / YY

Location:

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius?) Y (Y,N) If no, explain: except private drive

Sources of pollution/distance: 45' away from private drive

Surface water within 200'?  Y  N If yes, actual distance  If yes, bact. samples collected?  (Y,N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: good

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? N (Y,N)

Condition of house: good Type of freeze protection: elec. heater

Well: Diameter: 6 1/4 Type: drilled Yield (gpm): unk Properly sealed? N (Y,N)

Properly vented? Y (Y,N) Casing Depth unk ft (If unknown, put 'UNK') Well depth: unk Meter available? N (Y,N)

Concrete slab adequate? N (Y,N) If no, explain: close to edge of slab 6x6 Size: 18'r

Size of blow-off: none Sample tap?: Before treatment? Y (Y,N) After Treatment? Y (Y,N)

Pumps: Capacity: GPM: unk HP: unk Pump intake depth: unk Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing):     / 2"

Storage at well site: Elev:  Hydro: 0,100 Ground:

If hydro, air volume control? Y (Y,N) Safety valves: na (Y,N) Coded? na (Y,N)

High service pumps: 1.     gpm     hp 2.     gpm     hp 3.     gpm     hp Auxiliary power?     (Y,N)

Is water treated?  (Y,N) If yes, complete back of form.

If other wells are treated here, which ones?     If treated elsewhere, where?    

If purchase, retreat?  (Y/N) If yes, complete back of form.