

047

### SOURCE INFORMATION GROUND WATER

Date Form Completed  
**12/08/05**

PWS  
01-95-146

Owner Assigned

Source Code **S02** Well Name (If purchase, name of seller) **Well 2**

Code G=Ground  
W=Purchase/G  
**G** Y=G w/direct influence  
Z=W w/direct influence

Availability

P=Permanent  
**P** E=Emergency I=Interim  
S=Seasonal O=Other

If purchase, seller ID# \_\_\_\_\_ Source Begin Date \_\_\_\_\_ Direct Influence Date \_\_\_\_\_  
MM - YY MM - DD - YY

Location of well within the system (If purchase, location of master meter)

**near cabin 7**

Latitude (N)  
Deg. Min Sec

Longitude (W)  
Deg. Min Sec

How Determined

**G** G=GPS  
M=Map  
S=Surveyed  
D=Differential GPS

GPS File Name **U112816B-2000**

**36-12-23.13**

**81-44-22.83**

MM - DD - YY

If purchase, use seller's primary source lat/long)

Vulnerable VOC's  Y  
 N

Assessment Date: \_\_\_\_\_

### ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code **200** Entry Point Name **Well 2**

Use Code **C** C=Ground/Permanent  
D=Ground/non-Permanent

Availability **P** P=Year-round S=Seasonal  
E=Emergency I=Interim O=Other

Entry Point Begin Date

Entry Point End Date

MM / YY

MM / YY

Location: \_\_\_\_\_

Well Site: Owned or controlled? **Y** (Y,N) Control Area (100' radius?) **N** (Y,N) If no, explain: **20' to private resid.**

Sources of pollution/distance: \_\_\_\_\_

Surface water within 200'? **N** <sup>Y</sup>/<sub>N</sub> If yes, actual distance \_\_\_\_\_ If yes, bact. samples collected? \_\_\_\_\_ (Y/N)

Adequate slope? **Y** (Y,N) Flooding? **N** (Y,N) Maintenance: **good**

Well House: Free of stored materials? **Y** (Y,N) Properly drained? **Y** (Y,N) Locked? **N** (Y,N)

Condition of house: **excellent** Type of freeze protection: **elec. heater**

Well: Diameter: **6 1/4** Type: **drilled** Yield (gpm): **unk** Properly sealed? **Y** (Y,N)

Properly vented? **Y** (Y,N) Casing Depth **unk** <sup>(If unknown, put 'UNK')</sup> ft Well depth: **unk** Meter available? **Y** (Y,N)

Concrete slab adequate? **N** (Y,N) If no, explain: **close to edge of slab 6x6** Size: **18'r**

Size of blow-off: **none** Sample tap?: Before treatment? **Y** (Y,N) After Treatment? **Y** (Y,N)

Pumps: Capacity: GPM: **unk** HP: **unk** Pump intake depth: **unk** Auxiliary Power? **N** (Y,N)

Type pump: **submersible** Height above floor (pump/casing): \_\_\_\_\_ / **6"**

Storage at well site: Elev: \_\_\_\_\_ Hydro: **0,040** Ground: \_\_\_\_\_

If hydro, air volume control? **Y** (Y,N) Safety valves: **na** (Y,N) Coded? **na** (Y,N)

High service pumps: 1. \_\_\_\_\_ gpm hp 2. \_\_\_\_\_ gpm hp 3. \_\_\_\_\_ gpm hp Auxiliary power? \_\_\_\_\_ (Y,N)

Is water treated? **Y** (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? **well 3** If treated elsewhere, where? \_\_\_\_\_

If purchase, retreat? \_\_\_\_\_ (Y/N) If yes, complete back of form.