

SOURCE INFORMATION GROUND WATER

Date Form Completed

10/27/06

055

01-95-159

PWS

Owner Assigned

Source Code

Well Name (If purchase, name of seller)

W03

Well 3

Code G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

G

Availability

P=Permanent
E=Emergency I=Interim
S=Seasonal O=Other

P

If purchase, seller ID#

Source Begin Date

Direct Influence Date

MM - YY

MM - DD - YY

Location of well within the system (If purchase, location of master meter)

left side of parking lot as you enter parking area

Latitude (N)

Longitude (W)

How Determined

Deg. Min Sec

Deg. Min Sec

G=GPS

M=Map

S=Surveyed

D=Differential GPS

GPS File Name R022814A-1996

36-13-58.71

81-39-44.15

G

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's

Y
N

Assessment Date

ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code

Entry Point Name

W03

Well 3

Use Code

Availability

Entry Point Begin Date

Entry Point End Date

C=C=Ground/Permanent
D=D=Ground/non-Permanent

P=P=Year-round S=Seasonal
E=Emergency I=Interim O=Other

MM / YY

MM / YY

Location:

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius?) N (Y,N) If no, explain:

Sources of pollution/distance: 50' to bldg., parking adjacent to well, dumpster 10'

Surface water within 200'? N^Y_N If yes, actual distance: If yes, bact. samples collected? (Y/N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: good

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? N (Y,N)

Condition of house: good, new roof Type of freeze protection: none

Well: Diameter: 6 1/4" Type: drilled 1970? Yield (gpm): unk Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth unk ft (If unknown, put 'UNK') Well depth: unk Meter available? N (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: Size: 3'r

Size of blow-off: none Sample tap?: Before treatment? Y (Y,N) After Treatment? n/a (Y,N)

Pumps: Capacity: GPM: unk HP: unk Pump intake depth: unk Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 48"

Storage at well site: Elev:

Hydro:

Ground:

If hydro, air volume control? (Y,N) Safety valves: (Y,N) Coded? (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated? N (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.