

058

SOURCE INFORMATION GROUND WATER

Date Form Completed

09/20/05

PWS
01-95-161

Owner Assigned

Source Code Well Name (If purchase, name of seller)

000 Well 1

Code G=Ground
W=Purchase/G
G Y=G w/direct influence
Z=W w/direct influence

If purchase, seller ID# Source Begin Date Direct Influence Date
MM - YY MM - DD - YY

Availability
P=Permanent
E=Emergency I=Interim
S=Seasonal O=Other

Location of well within the system (If purchase, location of master meter)

next to campground office

Latitude (N) Longitude (W) How Determined
Deg. Min Sec Deg. Min Sec

36-15-50.54

81-45-35.17

G G=GPS
M=Map
S=Surveyed
D=Differential GPS

GPS File Name U082613A-1998

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's Y
 N

Assessment Date

ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code Entry Point Name

001 Office

Use Code Availability Entry Point Begin Date Entry Point End Date
C=Ground/Permanent P=Year-round S=Seasonal
D=Ground/non-Permanent E=Emergency I=Interim O=Other

05-94

MM/YY

MM/YY

Location: sample tap in office after storage tank

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius?) N (Y,N) If no, explain: office 10'

Sources of pollution/distance: driveways 10', building 10' camp sites w/in 100'

Surface water within 200'? N^Y_N If yes, actual distance If yes, bact. samples collected? (Y,N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: good

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? N (Y,N)

Condition of house: good, tile w/lid Type of freeze protection: insulated

Well: Diameter: 6 1/4" Type: drilled 1986 Yield (gpm): 30est Properly sealed? N (Y,N)

Properly vented? Y (Y,N) Casing Depth 64 ft (If unknown, put 'UNK') Well depth: 165' Meter available? N (Y,N)

Concrete slab adequate? N (Y,N) If no, explain: no slab Size: 0

Size of blow-off: none Sample tap?: Before treatment? Y (Y,N) After Treatment? n/a (Y,N)

Pumps: Capacity: GPM: unk HP: 1 1/2 Pump intake depth: 150' Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 3"

Storage at well site: Elev: Hydro: Ground:

If hydro, air volume control? Y (Y,N) Safety valves: n/a (Y,N) Coded? n/a (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated? N (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.