

### SOURCE INFORMATION GROUND WATER

Date Form Completed

01/25/07

367

01-95-176

PWS

Owner Assigned

Source Code

Well Name (If purchase, name of seller)

W20

Well #20

Code G=Ground

W=Purchase/G

G

Y=G w/direct influence

Z=W w/direct influence

Availability

P=Permanent

E=Emergency

S=Seasonal

I=Interim

O=Other

If purchase, seller ID#

Source Begin Date

Direct Influence Date

MM - YY

MM - DD - YY

Location of well within the system (If purchase, location of master meter)

inside well house

Latitude (N)

Longitude (W)

How Determined

Deg. Min Sec

Deg. Min Sec

G=GPS

M=Map

S=Surveyed

D=Differential GPS

GPS File Name U010516A-2001

36-10-22.31

81-33-45.25

G

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's  Y  N

Assessment Date

### ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code

Entry Point Name

EP1

Storage Valve Vault

Use Code

Availability

Entry Point Begin Date

Entry Point End Date

C=Ground/Permanent  
D=Ground/non-Permanent

P=Year-round S=Seasonal  
E=Emergency I=Interim O=Other

01-01

MM / YY

MM / YY

Location: tap in valve vault between the 300k ground storage tank and the 5k hydropneumatic tank

Well Site: Owned or controlled?  Y (Y,N) Control Area (100' radius?)  Y (Y,N) If no, explain:

Sources of pollution/distance: none

Surface water within 200'?  N  Y If yes, actual distance \_\_\_\_\_ If yes, bact. samples collected? \_\_\_\_\_ (Y/N)

Adequate slope?  Y (Y,N) Flooding?  N (Y,N) Maintenance: good

Well House: Free of stored materials?  Y (Y,N) Properly drained?  Y (Y,N) Locked?  Y (Y,N)

Condition of house: good Type of freeze protection: insulated and heated

Well: Diameter: 6 1/4" Type: drilled 10-21-97 Yield (gpm): 17 Properly sealed?  Y (Y,N)

Properly vented?  Y (Y,N) Casing Depth: 84 ft (If unknown, put 'UNK') Well depth: 900 Meter available?  Y (Y,N)

Concrete slab adequate?  Y (Y,N) If no, explain: \_\_\_\_\_ Size: 4'r

Size of blow-off: 2" Sample tap?: Before treatment?  Y (Y,N) After Treatment?  Y (Y,N)

Pumps: Capacity: GPM: 17 HP: 5 Pump intake depth: 875 Auxiliary Power?  N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 12"

Storage at well site: Elev: \_\_\_\_\_ Hydro: \_\_\_\_\_ Ground: \_\_\_\_\_

If hydro, air volume control? (Y,N) Safety valves: (Y,N) Coded? (Y,N)

High service pumps: 1. \_\_\_\_\_ gpm hp 2. \_\_\_\_\_ gpm hp 3. \_\_\_\_\_ gpm hp Auxiliary power? (Y,N)

Is water treated?  Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? 21 and 22 If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.