

079

SOURCE INFORMATION
GROUND WATER

Date Form Completed

11/10/05

PWS
01-95-432

Owner Assigned

Source Code Well Name (If purchase, name of seller)

W01 Well 2

Code G=Ground
W=Purchase/G
G Y=G w/direct influence
Z=W w/direct influence

If purchase, seller ID# Source Begin Date Direct Influence Date
MM - YY MM - DD - YY

Availability
P=Permanent I=Interim
E=Emergency O=Other
S=Seasonal

Location of well within the system (If purchase, location of master meter)

behind lodge 175'

Latitude (N) Longitude (W)
Deg. Min Sec Deg. Min Sec

36-08-08.63 81-48-55.46

How Determined

G=GPS
G M=Map
S=Surveyed
D=Differential GPS

GPS File Name S022014A-1998

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's Y
 N

Assessment Date

ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code Entry Point Name

E01 Booster Station

Use Code Availability Entry Point Begin Date Entry Point End Date

C=Ground/Permanent P=Year-round S=Seasonal
D=Ground/non-Permanent E=Emergency I=Interim O=Other

MM / YY

MM / YY

Location: in basement

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius?) Y (Y,N) If no, explain:

Sources of pollution/distance:

Surface water within 200'? Y N If yes, actual distance If yes, bact. samples collected? (Y/N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: good

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: good (new) Type of freeze protection: elec heat and insulated

Well: Diameter: 6 1/4" Type: drilled ~1970 Yield (gpm): 19.5 Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth 260 ft (If unknown, but 'UNK') Well depth: 300+ Meter available? Y (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: Size: 4'r

Size of blow-off: 1 1/2" Sample tap?: Before treatment? Y (Y,N) After Treatment? Y (Y,N)

Pumps: Capacity: GPM: unk HP: 1 Pump intake depth: unk Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 12"

Storage at well site: Elev: Hydro: Ground:

If hydro, air volume control? Y (Y,N) Safety valves: na (Y,N) Coded? na (Y,N)

High service pumps: 1. 50 gpm 1.5 hp 2. gpm hp 3. gpm hp Auxiliary power? N (Y,N)

Is water treated? Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.