

083

### SOURCE INFORMATION GROUND WATER

Date Form Completed

03/16/07

01-95-440

PWS

Owner Assigned

Source Code

Well Name (If purchase, name of seller)

W02

Well 2

Code G=Ground  
W=Purchase/G  
Y=G w/direct influence  
Z=W w/direct influence

G

If purchase, seller ID#

Source Begin Date

Direct Influence Date

Availability

MM - YY

MM - DD - YY

P=Permanent  
E=Emergency  
S=Seasonal  
I=Interim  
O=Other

P

Location of well within the system (If purchase, location of master meter)

50' from Hwy 421 next to white house downhill from resthome

Latitude (N)

Longitude (W)

How Determined

Deg. Min Sec

Deg. Min Sec

G=GPS  
M=Map  
S=Surveyed  
D=Differential GPS

GPS File Name D061312A-2000

36-13-25.41

81-42-26.15

G

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's  Y  N

Assessment Date

### ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code

Entry Point Name

E01

Storage Facility

Use Code

Availability

Entry Point Begin Date

Entry Point End Date

C=Ground/Permanent  
D=Ground/non-Permanent

P=Year-round  
E=Emergency  
S=Seasonal  
I=Interim  
O=Other

MM / YY

MM / YY

Location: common entry with well 1

Well Site: Owned or controlled?  Y (Y,N) Control Area (100' radius?)  N (Y,N) If no, explain: no lot

Sources of pollution/distance: 50' hwy 421, front yard of house,

Surface water within 200'?  Y  N If yes, actual distance  If yes, bact. samples collected?  (Y/N)

Adequate slope?  Y (Y,N) Flooding?  N (Y,N) Maintenance: fair

Well House: Free of stored materials?  Y (Y,N) Properly drained?  Y (Y,N) Locked?  N (Y,N)

Condition of house: good, tile with lid Type of freeze protection: insulated

Well: Diameter: 6 1/4" Type: drilled 1966? Yield (gpm): 20est Properly sealed?  Y (Y,N)

Properly vented?  N (Y,N) Casing Depth unk ft (If unknown, put 'UNK') Well depth: 120 Meter available?  Y\*\* (Y,N)

Concrete slab adequate?  Y (Y,N) If no, explain: Size: 3'r

Size of blow-off: none Sample tap?: Before treatment?  Y (Y,N) After Treatment?  n/a (Y,N)

Pumps: Capacity: GPM: unk HP: 1 1/2 Pump intake depth: unk Auxiliary Power?  N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 6"

Storage at well site: Elev: Hydro: Ground:

If hydro, air volume control? (Y,N) Safety valves: (Y,N) Coded? (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated?  N (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat?  (Y/N) If yes, complete back of form.