

089

SOURCE INFORMATION GROUND WATER

Date Form Completed

06/21/07

01-95-448

P.W.S

Owner Assigned

Source Code **G10** Well Name (If purchase, name of seller) **Well 2**

Code G=Ground
W=Purchase/G
G Y=G w/direct influence
Z=W w/direct influence

If purchase, seller ID# Source Begin Date Direct Influence Date
MM - YY MM - DD - YY

Availability
P=Permanent
P E=Emergency I=Interim
S=Seasonal O=Other

Location of well within the system (If purchase, location of master meter)
next to lot A-19

Latitude (N) Longitude (W)
Deg. Min Sec Deg. Min Sec
36-11-36.78 81-42-37.21

How Determined
G=GPS
G M=Map
S=Surveyed
D=Differential GPS
GPS File Name **R051515A**
MM - DD - YY

If purchase, use seller's primary source lat/long

Vulnerable VOC's Y
 N

Assessment Date

ENTRY POINT INFORMATION

Owner Assigned
Entry Point Code **G10** Entry Point Name **Well 2**

Use Code Availability Entry Point Begin Date Entry Point End Date
C C=Ground/Permanent P=Year-round S=Seasonal
D=Ground/non-Permanent **S** E=Emergency I=Interim O=Other
MM / YY MM / YY

Location: **in well house**

Well Site: Owned or controlled? **Y** (Y,N) Control Area (100' radius?) **N** (Y,N) If no, explain:

Sources of pollution/distance: **camper sewer connection 35' to 40' away, gravity sewer line**

Surface water within 200'? Y N If yes, actual distance If yes, bact. samples collected? (Y/N)

Adequate slope? **Y** (Y,N) Flooding? **N** (Y,N) Maintenance: **good**

Well House: Free of stored materials? **Y** (Y,N) Properly drained? **Y** (Y,N) Locked? **Y** (Y,N)

Condition of house: **needs repair** Type of freeze protection: **none-drained in winter**

Well: Diameter: **6 1/4"** Type: **drilled** **1973** Yield (gpm): **35** Properly sealed? **Y** (Y,N)

Properly vented? **Y** (Y,N) Casing Depth **55** ft (If unknown, put 'UNK') Well depth: **104'** Meter available? **N** (Y,N)

Concrete slab adequate? **Y** (Y,N) If no, explain: Size: **3'r**

Size of blow-off: **1 1/4"** Sample tap?: Before treatment? **Y** (Y,N) After Treatment? **n/a** (Y,N)

Pumps: Capacity: GPM: **unk** HP: **2** Pump intake depth: **95'** Auxiliary Power? **N** (Y,N)

Type pump: **submersible** Height above floor (pump/casing): / **6"**

Storage at well site: Elev: Hydro: **1,000** Ground:

If hydro, air volume control? - (Y,N) Safety valves: - (Y,N) Coded? - (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated? N (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.