

090

SOURCE INFORMATION GROUND WATER

Date Form Completed

06/21/01

PWS ID
01-95-449

Assigned

Source Code **W01** Well Name **WELL #1**

Code **G** Source Begin Date **MM / YY** Availability **P**
G = Ground P = Permanent
Y = G w/direct influence E = Emergency I = Interim
(GWUDI) S = Seasonal O = Other

Location of well within the system
Infront of building

Latitude (N) **36-15-17.12** Longitude (W) **81-46-15.95** How Determined **G**
Deg. Min Sec Deg Min Sec G=GPS
M=Map
S=Surveyed
D=Differential GPS
GPS File Name: **U022016A (2001)**

ENTRY POINT INFORMATION

System Monitoring? **N** (Y/N)

Assigned
Entry Point Code **E01** Entry Point Name **kitchen sink**

Use Code **C** Availability **P** Entry Point Begin Date **03/01** Entry Point End Date **MM / YY**
C=Ground/Permanent P=Permanent S=Seasonal E=Emergency I=Interim O=Other
(1st Sample is Due)

Location: **kitchen sink**

Well Site: Owned or controlled? **Y** (Y/N) Control Area (100' radius?) **N** (Y/N) If no, explain: **parking 0'**
Sources of pollution/distance: **road 50'**

Surface water within 200'? **N** (Y/N) If yes, actual distance **MM / YY** If yes, bact. samples collected? **Y** (Y/N)
Adequate slope? **Y** (Y/N) Flooding? **N** (Y/N) Site maintained? **Y** (Y/N)
Well House: Properly drained? **Y** (Y,N) Locked? **N** (Y,N) Free of stored material? **Y** (Y/N)
Condition of house: **good tile/lid** Type of freeze protection: **INSULATION**
Well: Diameter: **6 1/4** Type: **DRILLED** (Example: Drilled) Yield (gpm) **30** Properly sealed? **Y** (Y,N)
Properly vented? **Y** (Y,N) Casing Depth **90** ft. (If unknown, put "unk")
Screened interval(s): **mm-dd-yy** Drilling Contractor: **Dewey Wright Reg. #266** Date Completed: **5/22/97**
Concrete slab >= 3 ft. radius? **Y** (Y/N) If no, explain: **mm-dd-yy** Concrete slab cracked? **N** (Y,N)
Total depth (ft.) **285** Open interval: **mm-dd-yy** Sample tap?: Before treatment? **Y** (Y/N) After treatment? **Y** (Y/N)
Pumps: Capacity: GPM: **UNK** HP: **UNK** Height above floor (pump/casing): **12"**
Storage: Elevated: **MM / YY** (gallons) Hydro / bladder: **0,020** (gallons) Ground: **MM / YY** (gallons)
If hydro, pressure relief valves? **Y** (Y/N) Coded? **Y** (Y,N) Inspector tag? **Y** (Y/N)

TREATMENT INFORMATION

Is water treated? **N** (Y/N)
If other wells are treated here, which ones? **mm-dd-yy** If treated elsewhere, where? **mm-dd-yy**
DISINFECTION: (Hypochlorination - post (D4210)): **Y** (Y/N)
Chlorinator Make: **mm-dd-yy** Condition? **mm-dd-yy** Capacity: **mm-dd-yy**
Other type of disinfection: **mm-dd-yy**
Softening: (Ion Exchange (S4600)): **Y** (Y/N)
Other treatment: **mm-dd-yy**
Comments: **mm-dd-yy**