

107

SOURCE INFORMATION GROUND WATER

Date Form Completed

12/06/04

01-95-498

PWS

Owner Assigned

Source Code

Well Name (If purchase, name of system)

005

Well 1

Code G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

G

If purchase, seller ID#

Source Begin Date

Direct Influence Date

Availability

MM - YY

MM - DD - YY

P=Permanent
E=Emergency I=Interim
S=Seasonal O=Other

P

Location of well within the system (If purchase, location of master meter)

between wash and shop buildings

Latitude (N)

Longitude (W)

How Determined

Deg. Min Sec

Deg. Min Sec

G=GPS
M=Map
S=Surveyed
D=Differential GPS

36-14-38.92

81-39-24.99

G

GPS File Name U082512A-2000

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's Y N

Assessment Date

ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code

Entry Point Name

005

Well 1

Use Code

Availability

Entry Point Begin Date

Entry Point End Date

C=Ground/Permanent
D=Ground/non-Permanent

P=Year-round S=Seasonal
E=Emergency I=Interim O=Other

MM / YY

MM / YY

Location: well head

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius?) N (Y,N) If no, explain: truck parking

Sources of pollution/distance: scrap metal and steel beams within 100' radius

Surface water within 200'? Y N If yes, actual distance If yes, bact. samples collected? (Y/N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: good

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: good Type of freeze protection: partially under ground

Well: Diameter: 6 1/4" Type: drilled Yield (gpm): unk Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth unk ft (If unknown, put 'UNK') Well depth: unk Meter available? N (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: 16 x 20 feet Size: 4'r

Size of blow-off: 1" Sample tap?: Before treatment? Y (Y,N) After Treatment? na (Y,N)

Pumps: Capacity: GPM: unk HP: unk Pump intake depth: 140 Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 12"

Storage at well site: Elev: Hydro: 0,357 Ground:

If hydro, air volume control? Y (Y,N) Safety valves: na (Y,N) Coded? na (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated at this well? N (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.