

111

### SOURCE INFORMATION GROUND WATER

Date Form Completed

06/19/06

PWS ID  
01-95-503

Assigned

Source Code **W01** Well Name **Well #1**

Code **G** Source Begin Date **MM / YY** Availability **P**  
G = Ground P = Permanent  
Y = G w/direct influence E = Emergency I = Interim  
(GWUDI) S = Seasonal O = Other

Location of well within the system  
**in front of the shops next to entrance drive**

Latitude (N) **36-08-48.93** Longitude (W) **81-47-37.94** How Determined **D**  
Deg. Min Sec Deg. Min Sec G=GPS  
M=Map GPS File Name: **U051615B(2000)**  
S=Surveyed  
D=Differential GPS

### ENTRY POINT INFORMATION

System Monitoring? **Y** (Y/N)

Assigned

Entry Point Code **E01** Entry Point Name **well head**

Use Code **C** Availability **P** Entry Point Begin Date **MM / YY** Entry Point End Date **MM / YY**  
C=Ground/Permanent P=Permanent S=Seasonal E=Emergency I=Interim O=Other  
(1st Sample is Due)

Location: **well head**

Well Site: Owned or controlled? **Y** (Y/N) Control Area (100' radius?) **N** (Y/N) If no, explain: **parking lot 3 ft**  
Sources of pollution/distance: **road 20 ft, shops 45ft**

Surface water within 200'? **N** (Y/N) If yes, actual distance **MM / YY** If yes, bact. samples collected? **N** (Y/N)  
Adequate slope? **Y** (Y/N) Flooding? **N** (Y/N) Site maintained? **Y** (Y/N)

Well House: Properly drained? **Y** (Y,N) Locked? **N** (Y,N) Free of stored material? **Y** (Y/N)  
Condition of house: **good tile/lid** Type of freeze protection: **insulation**

Well: Diameter: **6 1/4** Type: **Drilled** (Example: Drilled) Yield (gpm) **30** Properly sealed? **Y** (Y,N)  
Properly vented? **Y** (Y,N) Casing Depth **31** ft. (If unknown, put "unk")  
Screened interval(s): **mm-dd-yy** Drilling Contractor: **unk** Date Completed: **4/17/1978**

Concrete slab >= 3 ft. radius? **Y** (Y/N) If no, explain: **mm-dd-yy** Concrete slab cracked? **N** (Y,N)  
Total depth (ft.) **150** Open interval: **mm-dd-yy** Sample tap?: Before treatment? **Y** (Y/N) After treatment? **Y** (Y/N)

Pumps: Capacity: GPM: **HP:** Height above floor (pump/casing): **18"**  
Storage: Elevated: **(gallons)** Hydro / bladder: **0,020** Ground: **(gallons)**  
If hydro, pressure relief valves? **(Y/N)** Coded? **(Y,N)** Inspector tag? **(Y/N)**

### TREATMENT INFORMATION

Is water treated? **N** (Y/N)  
If other wells are treated here, which ones? **mm-dd-yy** If treated elsewhere, where? **mm-dd-yy**

DISINFECTION: (Hypochlorination - post (D4210)): **(Y/N)**  
Chlorinator Make: **mm-dd-yy** Condition? **mm-dd-yy** Capacity: **mm-dd-yy**

Other type of disinfection: **mm-dd-yy**  
Softening: (Ion Exchange (S4600)): **(Y/N)**

Other treatment: **mm-dd-yy**  
Comments: **mm-dd-yy**