

104

SOURCE INFORMATION GROUND WATER

Date Form Completed

02/17/05

01-95-521

PWS

Owner Assigned

Source Code Well Name (If purchase, name of seller)

W01 Well 1

Code G=Ground
W=Purchase/G
G Y=G w/direct influence
Z=W w/direct influence

If purchase, seller ID# Source Begin Date Direct Influence Date
MM - YY MM - DD - YY

Availability
P=Permanent
E=Emergency I=Interim
S=Seasonal O=Other

Location of well within the system (If purchase, location of master meter)

in field 400 feet North of school building

Latitude (N) Longitude (W)
Deg. Min Sec Deg. Min Sec

36-19-30.48 81-44-43.57

How Determined

G=GPS
G M=Map
S=Surveyed
D=Differential GPS

GPS File Name U082514B-2000

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's Y
 N

Assessment Date

ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code Entry Point Name

E01 Boiler Room Tap

Use Code Availability Entry Point Begin Date Entry Point End Date
C=Ground/Permanent P=Year-round S=Seasonal
D=Ground/non-Permanent E=Emergency I=Interim O=Other
MM / YY MM / YY

Location: in boiler room

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius)? Y (Y,N) If no, explain:

Sources of pollution/distance:

Surface water within 200'? N (Y,N) If yes, actual distance If yes, bact. samples collected? (Y,N)

Adequate slope? N (Y,N) Flooding? N (Y,N) Maintenance: good

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: excellent Type of freeze protection: heated

Well: Diameter: 6 1/4 Type: drilled 11-29-89 Yield (gpm): 17 Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth: 135 ft (If unknown, put 'UNK') Well depth: 405' Meter available? Y (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: 15 x 15 feet Size: 4'r

Size of blow-off: 2" Sample tap?: Before treatment? Y (Y,N) After Treatment? Y (Y,N)

Pumps: Capacity: GPM: 15 HP: 3 Pump intake depth: unk Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 6"

Storage at well site: Elev: Hydro: 10,000 Ground:

If hydro, air volume control? Y (Y,N) Safety valves: Y (Y,N) Coded? Y (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated? Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.