

126

SOURCE INFORMATION GROUND WATER

Date Form Completed

08/09/07

01-95-522

PWS

Owner Assigned

Source Code Well Name (If purchase, name of seller)

W01 Well 1

Code G=Ground
W=Purchase/G
G Y=G w/direct influence
Z=W w/direct influence

If purchase, seller ID# Source Begin Date Direct Influence Date
MM - YY MM - DD - YY

Availability
P=Permanent
E=Emergency I=Interim
S=Seasonal O=Other

Location of well within the system (If purchase, location of master meter)

behind the construction company shop

Latitude (N) Longitude (W)
Deg. Min Sec Deg. Min Sec

36-13-13.31 81-42-46.58

How Determined

G=GPS
G M=Map
S=Surveyed
D=Differential GPS

GPS File Name U062815A-2000

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's Y
 N

Assessment Date

ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code Entry Point Name

001 Kitchen sink

Use Code Availability Entry Point Begin Date Entry Point End Date

C=Ground/Permanent
D=Ground/non-Permanent
P=Year-round
E=Emergency S=Seasonal
I=Interim O=Other

MM / YY

MM / YY

Location: kitchen sink

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius)? N (Y,N) If no, explain: no lot at all

Sources of pollution/distance: building 1", drum storage 40', equipment and repair area adjacent

Surface water within 200'? N (Y,N) If yes, actual distance If yes, bact. samples collected? (Y/N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: poor

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? N (Y,N)

Condition of house: good, tile w/lid Type of freeze protection: minimal insulation

Well: Diameter: 6 1/4" Type: drilled 4-8-77 Yield (gpm): 10 Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth 46 ft (If unknown, put 'UNK') Well depth: 104' Meter available? (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: Size: 3'r

Size of blow-off: none Sample tap?: Before treatment? Y (Y,N) After Treatment? n/a (Y,N)

Pumps: Capacity: GPM: unk HP: unk Pump intake depth: unk Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 6"

Storage at well site: Elev: Hydro: Ground:

If hydro, air volume control? (Y,N) Safety valves: (Y,N) Coded? (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated? N (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.