

### SOURCE INFORMATION GROUND WATER

Date Form Completed

07/25/05

30-95-005

PWS

Owner Assigned

Source Code

Well Name (If purchase, name of seller)

S01

Well #1

Code  
G=Ground  
W=Purchase/G  
Y=G w/direct influence  
Z=W w/direct influence

G

If purchase, seller ID#

Source Begin Date  
MM - YY

Direct Influence Date  
MM - DD - YY

Availability

P=Permanent  
E=Emergency  
S=Seasonal  
I=Interim  
O=Other

P

Location of well within the system (If purchase, location of master meter)

uphill from office at "T" in gravel road

Latitude (N)  
Deg. Min Sec

Longitude (W)  
Deg. Min Sec

How Determined

G=GPS  
M=Map  
S=Surveyed  
D=Differential GPS

G

GPS File Name B072313A-2002

36-07-14.07

81-46-01.07

If purchase, use seller's primary source lat/long)

MM - DD - YY

Vulnerable VOC's  Y  N

Assessment Date

### ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code

Entry Point Name

E01

Kitchen

Use Code

C=Ground/Permanent  
D=Ground/non-Permanent

C

Availability

P=Year-round  
E=Emergency  
S=Seasonal  
I=Interim  
O=Other

P

Entry Point Begin Date

08/02

MM / YY

Entry Point End Date

MM / YY

Location: kitchcn sink

Well Site: Owned or controlled?  Y (Y,N) Control Area (100' radius?)  N (Y,N) If no, explain: no well lot

Sources of pollution/distance: house 50', gravel drive 5'

Surface water within 200'?  N  Y If yes, actual distance  If yes, bact. samples collected?  (Y/N)

Adequate slope?  Y (Y,N) Flooding?  N (Y,N) Maintenance: good

Well House: Free of stored materials?  Y (Y,N) Properly drained?  N (Y,N) Locked?  N (Y,N)

Condition of house: poor-tile w/lid Type of freeze protection: earth

Well: Diameter: 6 1/4" Type: drilled ~1950's Yield (gpm): unk Properly sealed?  N (Y,N)

Properly vented?  N (Y,N) Casing Depth: unk (If unknown, put 'UNK') ft Well depth: unk Meter available?  N (Y,N)

Concrete slab adequate?  N (Y,N) If no, explain: no slab Size: n/a

Size of blow-off: none Sample tap?: Before treatment?  N (Y,N) After Treatment?  N (Y,N)

Pumps: Capacity: GPM: unk HP: unk Pump intake depth: unk Auxiliary Power?  N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 18"

Storage at well site: Elev:  Hydro: 0,325 Ground:

If hydro, air volume control?  N (Y,N) Safety valves:  N (Y,N) Coded?  N (Y,N)

High service pumps: 1.  gpm  hp 2.  gpm  hp 3.  gpm  hp Auxiliary power?  (Y,N)

Is water treated?  N (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat?  (Y/N) If yes, complete back of form.