

### SOURCE INFORMATION GROUND WATER

Date Form Completed

03/22/05

30-95-009  
PWS

Owner Assigned

Source Code

Well Name (If purchase, name of seller)

S01

Well #3

Code

G=Ground  
W=Purchase/G  
Y=G w/direct influence  
Z=W w/direct influence

G

If purchase, seller ID#

Source Begin Date

Direct Influence Date

MM - YY

MM - DD - YY

Availability

P

P=Permanent  
E=Emergency  
S=Seasonal  
I=Interim  
O=Other

Location of well within the system (If purchase, location of master meter)

rear of 232 High Peak Dr. Actually located on Overlook Hill

Latitude (N)

Longitude (W)

How Determined

Deg. Min Sec

Deg. Min Sec

G=GPS  
M=Map  
S=Surveyed  
D=Differential GPS

36-09-36.375

81-36-54.157

D

GPS File Name U032215B-2005

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's

Y  
N

Assessment Date

### ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code

Entry Point Name

E01

Well House Tap

Use Code

Availability

Entry Point Begin Date

Entry Point End Date

C=C=Ground/Permanent  
D=D=Ground/non-Permanent

P=P=Year-round  
E=E=Emergency  
S=Seasonal  
I=Interim  
O=Other

07/03

MM / YY

MM / YY

Location: after storage

Well Site: Owned or controlled? N (Y,N) Control Area (100' radius?) N (Y,N) If no, explain: no well lot

Sources of pollution/distance: septic field 200 feet

Surface water within 200'? N<sup>Y</sup>/<sub>N</sub> If yes, actual distance [ ] If yes, bact. samples collected? [ ] (Y/N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: good

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: very good built 2002 Type of freeze protection: insulated and heated

Well: Diameter: 6 1/4" Type: drilled 8-21-85 Yield (gpm): 15 Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth: 41 ft (If unknown, put 'UNK') Well depth: 544' Meter available? N (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: Size: 3'r

Size of blow-off: none Sample tap?: Before treatment? Y (Y,N) After Treatment? Y (Y,N)

Pumps: Capacity: GPM: 4.7 HP: 1 1/2 Pump intake depth: unk Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 6"

Storage at well site: Elev: [ ] Hydro: 50 Ground: [ ]

If hydro, air volume control? (Y,N) Safety valves: (Y,N) Coded? (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated? Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.