

160

SOURCE INFORMATION GROUND WATER

Date Form Completed

05/18/06

30-95-010

PWS

Owner Assigned

Source Code

Well Name (If purchase, name of seller)

S01

Well #4

Code G=Ground

W=Purchase/G

Y=G w/direct influence

Z=W w/direct influence

G

If purchase, seller ID#

Source Begin Date

Direct Influence Date

MM - YY

MM - DD - YY

Availability

P=Permanent

E=Emergency

S=Seasonal

I=Interim

O=Other

P

Location of well within the system (If purchase, location of master meter)

end of Laurel Hill Ln., beyond lot 222 Laurel Hill Ln.

Latitude (N)

Longitude (W)

How Determined

Deg. Min Sec

Deg Min Sec

G=GPS

M=Map

S=Surveyed

D=Differential GPS

GPS File Name U032215A-2005

36-09-30.665

81-36-49.171

D

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's

Y
N

Assessment Date

ENTRY POINT INFORMATION

Owner Assigned

Entry Point Code

Entry Point Name

E01

Well House Tap

Use Code

Availability

Entry Point Begin Date

Entry Point End Date

C=Ground/Permanent
D=Ground/non-Permanent

P=Year-round S=Seasonal
E=Emergency I=Interim O=Other

07/03

MM / YY

MM / YY

Location: tap after storage

Well Site: Owned or controlled? N (Y,N) Control Area (100' radius?) N (Y,N) If no, explain: no well lot

Sources of pollution/distance: septic for 222 Laurel Hill Ln. 175 feet away

Surface water within 200'? N (Y,N) If yes, actual distance If yes, bact. samples collected? (Y/N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: good

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: new, good built 2002 Type of freeze protection: insulated, heater

Well: Diameter: 6 1/4" Type: drilled 4-10-89 Yield (gpm): 25 Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth 37 ft (If unknown, put 'UNK') Well depth: 304' Meter available? N (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: Size: 3'r

Size of blow-off: none Sample tap?: Before treatment? Y (Y,N) After Treatment? Y (Y,N)

Pumps: Capacity: GPM: 7 HP: 1 1/2 Pump intake depth: unk Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 4"

Storage at well site: Elev: Hydro: 50 Ground:

If hydro, air volume control? (Y,N) Safety valves: (Y,N) Coded? (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated? Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.