

162

**SOURCE INFORMATION**  
**GROUND WATER**

Date Form Completed

03/22/05

PWS  
30-95-012

Owner Assigned

Source Code

Well Name (If purchase, name of seller)

S01

Well #6

Code  
G=Ground  
W=Purchase/G  
Y=G w/direct influence  
Z=W w/direct influence

G

If purchase, seller ID#

Source Begin Date  
MM - YY

Direct Influence Date  
MM - DD - YY

Availability

P=Permanent  
E=Emergency  
S=Seasonal  
I=Interim  
O=Other

P

Location of well within the system (If purchase, location of master meter)

520 High Peak Drive

Latitude (N)

Longitude (W)

How Determined

Deg. Min Sec

Deg. Min Sec

G=GPS  
M=Map  
S=Surveyed  
D=Differential GPS

GPS File Name U032214C-2005

36-09-33.114

81-36-37.956

D

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's  Y  N

Assessment Date

**ENTRY POINT INFORMATION**

Owner Assigned

Entry Point Code

Entry Point Name

E01

Well House Tap

Use Code

Availability

Entry Point Begin Date

Entry Point End Date

C=C=Ground/Permanent  
D=D=Ground/non-Permanent

P=P=Year-round S=Seasonal  
E=Emergency I=Interim O=Other

07/03

MM / YY

MM / YY

Location: tap after storage

Well Site: Owned or controlled?  N (Y,N) Control Area (100' radius?)  N (Y,N) If no, explain: no well lot

Sources of pollution/distance: 275 feet to septic system for 520 High Peak Dr.

Surface water within 200'?  N  Y If yes, actual distance  If yes, bact. samples collected?  (Y/N)

Adequate slope?  Y (Y,N) Flooding?  N (Y,N) Maintenance: good

Well House: Free of stored materials?  Y (Y,N) Properly drained?  Y (Y,N) Locked?  N (Y,N)

Condition of house: fair Type of freeze protection: insulated, heater

Well: Diameter: 6 1/4" Type: drilled 11-16-90 Yield (gpm): 705' Properly sealed?  Y (Y,N)

Properly vented?  Y (Y,N) Casing Depth: 20 ft (If unknown, put 'UNK') Well depth: 705' Meter available?  N (Y,N)

Concrete slab adequate?  N (Y,N) If no, explain: too small Size: 18"

Size of blow-off: none Sample tap?: Before treatment?  Y (Y,N) After Treatment? n/a (Y,N)

Pumps: Capacity: GPM: 6 HP: 3/4 Pump intake depth: unk Auxiliary Power?  N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 6"

Storage at well site: Elev:  Hydro: 50 Ground:

If hydro, air volume control?  (Y,N) Safety valves:  (Y,N) Coded?  (Y,N)

High service pumps: 1.  gpm  hp 2.  gpm  hp 3.  gpm  hp Auxiliary power?  (Y,N)

Is water treated?  Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones?  If treated elsewhere, where?

If purchase, retreat?  (Y/N) If yes, complete back of form.