

165

**SOURCE INFORMATION**  
**GROUND WATER**

Date Form Completed

03/01/07

PWS  
30-95-015

Owner Assigned

Source Code Well Name (If purchase, name of seller)

**S01** **Well #1**

Code G=Ground  
 W=Purchase/G  
**G** Y=G w/direct influence  
 Z=W w/direct influence

Availability

P=Permanent  
**P** E=Emergency I=Interim  
 S=Seasonal O=Other

If purchase, seller ID# Source Begin Date Direct Influence Date  
 MM - YY MM - DD - YY

Location of well within the system (If purchase, location of master meter)

**right of drive entering the development**

Latitude (N) Longitude (W) How Determined

Deg. Min Sec

Deg. Min Sec

G=GPS  
**G** M=Map  
 S=Surveyed  
 D=Differential GPS

GPS File Name **U060815A-2004**

**36-16-35.88**

**81-38-52.38**

MM - DD - YY

If purchase, use seller's primary source lat/long)

Vulnerable VOC's Y  
 N

Assessment Date

**ENTRY POINT INFORMATION**

Owner Assigned

Entry Point Code Entry Point Name

**E01** **215-D Courtney Taylor Lane**

Use Code Availability Entry Point Begin Date Entry Point End Date

**C** C=Ground/Permanent P=Year-round S=Seasonal  
 D=Ground/non-Permanent E=Emergency I=Interim O=Other

**07/04**

MM / YY

MM / YY

Location: **outside spigot at this address**

Well Site: Owned or controlled? **Y** (Y,N) Control Area (100' radius?) **Y** (Y,N) If no, explain:

Sources of pollution/distance:

Surface water within 200'? **N** <sup>Y</sup>/<sub>N</sub> If yes, actual distance If yes, bact. samples collected? (Y/N)

Adequate slope? **Y** (Y,N) Flooding? **N** (Y,N) Maintenance: **good**

Well House: Free of stored materials? **Y** (Y,N) Properly drained? **Y** (Y,N) Locked? **Y** (Y,N)

Condition of house: **excellent** Type of freeze protection: **insulated and heated**

Well: Diameter: **6 1/4"** Type: **drilled 2003** Yield (gpm): **44** Properly sealed? **Y** (Y,N)

Properly vented? **Y** (Y,N) Casing Depth: **80** <sup>(If unknown, put 'UNK')</sup> ft Well depth: **300** Meter available? **Y** (Y,N)

Concrete slab adequate? **Y** (Y,N) If no, explain: Size: **3'r**

Size of blow-off: **1"** Sample tap?: Before treatment? **Y** (Y,N) After Treatment? **Y** (Y,N)

Pumps: Capacity: GPM: **32** HP: **5** Pump intake depth: **205** Auxiliary Power? **N** (Y,N)

Type pump: **submersible** Height above floor (pump/casing): / **36"**

Storage at well site: Elev: **0** Hydro: **0** Ground: **0**

If hydro, air volume control? **Y** (Y,N) Safety valves: **Y** (Y,N) Coded? **Y** (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated? **Y** (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where? **at storage tank**

If purchase, retreat? (Y/N) If yes, complete back of form.