

168

SOURCE INFORMATION GROUND WATER

Date Form Completed

05/24/07

01-95-459

PWS

Owner Assigned

Source Code Well Name (If purchase, name of system)

WE4 Well 4

Code G=Ground
W=Purchase/G
G Y=G w/direct influence
Z=W w/direct influence

If purchase, seller ID# Source Begin Date Direct Influence Date
MM - YY MM - DD - YY

Availability P=Permanent
E=Emergency I=Interim
S=Seasonal O=Other

Location of well within the system (If purchase, location of master meter)

in pasture with storage tank

Latitude (N) Longitude (W) How Determined
Deg. Min Sec Deg. Min Sec G=GPS
36-15-22.82 81-40-05.56 D M=Map
S=Surveyed GPS File Name S091116A-1997
D=Differential GPS

If purchase, use seller's primary source lat/long

MM - DD - YY

Vulnerable VOC's Y N Assessment Date

ENTRY POINT INFORMATION

Owner Assigned Entry Point Name

E04 Storage Tank

Use Code Availability Entry Point Begin Date Entry Point End Date
C=Ground/Permanent P=Year-round S=Seasonal 10-97
D=Ground/non-Permanent E=Emergency I=Interim O=Other MM / YY
MM / YY

Location: after treatment at well four

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius?) Y (Y,N) If no, explain:

Sources of pollution/distance:

Surface water within 200'? N Y N If yes, actual distance If yes, bact. samples collected? (Y/N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: well house under construction

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? N (Y,N)

Condition of house: under construction Type of freeze protection: turned off in winter

Well: Diameter: 6 1/4" Type: drilled 1-20-94 Yield (gpm): 10 Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing Depth: 50 ft (If unknown, put 'UNK') Well depth: 685' Meter available? Y (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: Size: 5'r

Size of blow-off: 2" Sample tap?: Before treatment? Y (Y,N) After Treatment? Y (Y,N)

Pumps: Capacity: GPM: 10 HP: 3 Pump intake depth: unk Auxiliary Power? N (Y,N)

Type pump: submersible Height above floor (pump/casing): / 6"

Storage at well site: Elev: Hydro: Ground: 12,000

If hydro, air volume control? na (Y,N) Safety valves: na (Y,N) Coded? na (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary power? (Y,N)

Is water treated at this well? Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? 2 and 5 If treated elsewhere, where?

If purchase, retreat? (Y/N) If yes, complete back of form.