



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION #

2878

050653

WS

320973

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)
DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 11/29/2005

TIME COMPLETED AM PM

3. WELL LOCATION:

CITY: FOSCOE COUNTY: WATAUGA

RED BANK OFF HWY 105

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3

LONGITUDE

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

May be in degrees, minutes, seconds or in a decimal format

5. WELL DETAILS:

a. TOTAL DEPTH: 405

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 50 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 12 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 71

g. WATER ZONES (depth):
From 251 To 252 From 331 To 331
From 370 To 371 From To
From To From To

6. CASING: Thickness/
Depth Diameter Weight Material
From 0 To 123 Ft. 8 1/8 350 PVC
From To Ft.
From To Ft.

7. GROUT: Depth Material Method
From 0 To 20 Ft. Cement Gravity Flow
From To Ft.
From To Ft. Cement Gravity Flow

8. SCREEN: Depth Diameter Slot Size Material
From To Ft. in. in. in.
From To Ft. in. in. in.
From To Ft. in. in. in.

9. SAND/GRAVEL PACK: Size
Depth
From To Ft.
From To Ft.
From To Ft.

Material RECEIVED
N.C. DEPT. OF ENV.
JAN 23 2006
Winston-Salem
Regional
Materials Office

10. DRILLING LOG

From	To	Formation Description
0	117	DIRT ROCK
117	251	GRANITE
251	252	QUARTZ
252	330	GRANITE
330	331	QUARTZ
331	370	GRANITE
370	371	QUARTZ
371	405	GRANITE

11. REMARKS:

2 GPM 251 - 252 1 GPM 330 - 331
0 GPM 370 - 371 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Signature: Steven Price 2/14/05
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE
STEVE PRICE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL