



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878

320974

050666

WS

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2651

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 12/1/2005

TIME COMPLETED _____ AM PM

3. WELL LOCATION:

CITY: BOONE COUNTY: WATAUGA

LOWER RUSH BRANCH RD. OFF 321 OFF 421

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3

LONGITUDE _____

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 205

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 40 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 20 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 35

g. WATER ZONES (depth):

From 06 To 98 From 190 To 191

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Thickness/

Depth Diameter Weight Material
From 0 To 65 Ft. 6 1/8 .350 PVC

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

Depth Material Method
From 0 To 20 Ft. Cement Gravity Flow

From _____ To _____ Ft. _____

From _____ To _____ Ft. Cement Gravity Flow

8. SCREEN:

Depth Diameter Slot Size Material
From _____ To _____ Ft. _____ in. _____ in.

From _____ To _____ Ft. _____ in. _____ in.

From _____ To _____ Ft. _____ in. _____ in.

9. SAND/GRAVEL PACK:

Depth Size Material
From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

RECEIVED
N.C. DEPT. OF ENV
JAN 23 2006
Winston-Salem
Regional Office

10. DRILLING LOG

From	To	Formation Description
0	59	DIRT
59	95	GRANITE
95	98	SHALE
98	190	GRANITE
190	191	RED GRANITE
191	205	GRANITE

11. REMARKS:

1 GPM 96 - 98 19 GPM 190 - 191

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steven Price 1/19/05
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL