



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2878

WS

320976

050408-3

1. WELL CONTRACTOR:

STEVE PRICE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2651

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID # (if applicable)

STATE WELL PERMIT # (if applicable)

DWQ or OTHER PERMIT # (if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 10/23/2005

TIME COMPLETED AM PM

3. WELL LOCATION:

CITY: BOONE COUNTY: WATAUGA

MORNING GLORY OFF BRIGHTWOOD II OFF POW

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other (check appropriate box)

LATITUDE 3

LONGITUDE

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 405

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 50 FT. (Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 4 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 71

g. WATER ZONES (depth):

Front 00-101 To From 230-231 To

Front 372-374 To From To

From To From To

6. CASING: Thickness/

From 0 To 42 Ft. 6 1/8 350 PVC

From To Ft.

From To Ft.

7. GROUT: Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From To Ft.

From To Ft. Cement Gravity Flow

8. SCREEN: Depth Diameter Slot Size Material

From To Ft. in. in.

From To Ft. in. in.

From To Ft. in. in.

9. SAND/GRAVEL PACK:

Depth Size

From To Ft.

From To Ft.

From To Ft.

RECEIVED
N.C. DEPT. OF ENR
JAN 23 2006

Winston-Salem
Regional Office

10. DRILLING LOG

From	To
0	36
36	100
100	101
101	230
230	231
231	372
372	374
374	405

Formation Description

DIRT

GRANITE

GRANITE

GRANITE

QUARTZ

GRANITE

QUARTZ

GRANITE

11. REMARKS:

0.5 GPM 100-101 - 1.5 GPM 230-231 -

2 GPM 372-374 - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Signature of Steven Price 12/14/05

SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PRICE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a Rev. 7/05