RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WS

322293

WELL CONTRACTOR CERTIFICATION # 2681

050692

1. WELL CONTRACTOR:

STEVE PETTY
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O BOX 303

BOONE NC 28607
City or Town State Zip Code

(828) - 264-2661
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply ☒

DATE DRILLED 1/2/2006

TIME COMPLETED 5:30 AM ☐ PM ☒

3. WELL LOCATION:

CITY: BOONE COUNTY WATAUGA

VIEW RD. OFF CHESTNUT HILL RD. OFF OLD TUR
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☒ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 3 36.16001
LONGITUDE 081.73255

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☒ GPS ☐ Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. **TOTAL DEPTH:** 405

b. **DOES WELL REPLACE EXISTING WELL?** YES ☐ NO ☒

c. **WATER LEVEL** Below Top of Casing: 50 FT.
(Use "+" if Above Top of Casing)

d. **TOP OF CASING IS** 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. **YIELD (gpm):** 15 **METHOD OF TEST** Air

f. **DISINFECTION: Type** HTH **Amount** 71

g. **WATER ZONES** (depth):

From 120 To 121 From 386 To 387
From To From To
From To From To

6. CASING:

From	To	Ft.	Diameter	Thickness/ Weight	Material
0	93		6 1/8	350	PVC
0	0				

7. GROUT:

From	To	Ft.	Material	Method
0	20		Cement	Gravity Flow

8. SCREEN:

From	To	Ft.	Diameter	Slot Size	Material
			in.	in.	
			in.	in.	
			in.	in.	

9. SAND/GRAVEL PACK:

From	To	Ft.	Size	Material

10. DRILLING LOG

From	To	Formation Description
0	90	DIRT
90	120	GRANITE
120	121	SHALE
121	386	GRANITE
386	387	SHALE
387	405	GRANITE

11. REMARKS:

0.5 GPM 120 - 121 14.5 GPM 386 - 387
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Petty 1-17-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE PETTY
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

FEB 1 1 06

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05