WSRD

323287

RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2686

050703-1

1. WELL CONTRACTOR:

LESLIE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P O BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 264-2651

Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply ☑

DATE DRILLED 1/12/2006

TIME COMPLETED 12:00 AM ☐ PM ☑

3. WELL LOCATION:

CITY: BANNER ELK COUNTY WATAUGA

LOT 8 -TWIN PONDS OFF ROCKY PARKWAY OFF

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

☑ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other

(check appropriate box)

LATITUDE 3 36.20227

LONGITUDE 081.84845

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☑ GPS ☐ Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. **TOTAL DEPTH:** 1000

b. **DOES WELL REPLACE EXISTING WELL?** YES ☐ NO ☑

c. **WATER LEVEL** Below Top of Casing: _____ FT.
(Use "+" if Above Top of Casing)

d. **TOP OF CASING IS** 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. **YIELD (gpm):** 0 **METHOD OF TEST** Air

f. **DISINFECTION: Type** HTH **Amount**

g. **WATER ZONES** (depth):

From DRY HOLE To From To

From To From To

From To From To

6. CASING:

	Depth		Diameter	Thickness/ Weight	Material
From 0	To 60	Ft.	6 1/8	.350	PVC
From 0	To 0	Ft.			
From	To	Ft.			

7. GROUT:

	Depth		Material	Method
From 0	To 20	Ft.	Cement	Gravity Flow
From	To	Ft.		
From	To	Ft.		

8. SCREEN:

	Depth		Diameter	Slot Size	Material
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	

9. SAND/GRAVEL PACK:

	Depth		Size	Material
From	To	Ft.		
From	To	Ft.		
From	To	Ft.		

10. DRILLING LOG

From	To	Formation Description
0	55	DIRT
55	1000	GRANITE

11. REMARKS:

0 GPM DRY HOLE - 0 GPM -

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Leslie Wayne Reece 2-21-06

SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

LESLIE REECE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05