WS

324432

RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 3691

1. WELL CONTRACTOR:

STEVE PETTY
Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.
Well Contractor Company Name

STREET ADDRESS P. O. BOX 208

BOONE | NC | 28607
City or Town | State | Zip Code

(828) - 264-2861
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)
STATE WELL PERMIT #(if applicable)
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box): Residential Water Supply ☑
DATE DRILLED 2/15/2006
TIME COMPLETED 8:20 AM ☐ PM ☑

3. WELL LOCATION:

CITY: BOONE COUNTY WATAUGA

CAMP ROCK RD. OFF DEERFIELD RD. OFF 321
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☑ Ridge ☐ Other
(check appropriate box)

May be in degrees, minutes, seconds or in a decimal format

LATITUDE 3 36 12.012
LONGITUDE 81 37.200
Latitude/longitude source: ☑ GPS ☐ Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. **TOTAL DEPTH:** 405
b. **DOES WELL REPLACE EXISTING WELL?** YES ☐ NO ☑
c. **WATER LEVEL** Below Top of Casing: 50 FT.
(Use "+" if Above Top of Casing)
d. **TOP OF CASING IS** 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118
e. **YIELD (gpm):** 4 **METHOD OF TEST** Air

f. **DISINFECTION: Type** HTH **Amount** 71
g. **WATER ZONES** (depth):
From 250 To 251 From 300 To 301
From To From To
From To From To

6. CASING:

	Depth	Diameter	Thickness/ Weight	Material
From 0	To 24	Ft. 6 1/8	350	PVC
From 0	To 0	Ft.		
From	To	Ft.		

7. GROUT:

	Depth	Material	Method
From 0	To 20	Ft. Cement	Gravity Flow
From	To	Ft.	
From	To	Ft.	

8. SCREEN:

	Depth	Diameter	Slot Size	Material
From	To	Ft. in.	in.	
From	To	Ft. in.	in.	
From	To	Ft. in.	in.	

9. SAND/GRAVEL PACK:

	Depth	Size	Material
From	To	Ft.	
From	To	Ft.	
From	To	Ft.	

10. DRILLING LOG

From	To	Formation Description
0	20	DIRT
20	250	GRANITE
250	251	SHALE
251	300	GRANITE
300	301	SHALE
301	405	GRANITE

11. REMARKS:

2 GPM 250 - 251 2 GPM 300 - 301
0 GPM - 0 GPM -
0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Petty — 3-20-06
SIGNATURE OF CERTIFIED WELL CONTRACTOR — DATE

STEVE PETTY
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05