

WS

324449



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2887

050581

1. WELL CONTRACTOR:

STEVE REECE
 Well Contractor (Individual Name)
DEWEY WRIGHT WELL & PUMP CO., INC.
 Well Contractor Company Name
 STREET ADDRESS P.O. BOX 302
BOONE NC 28607
 City or Town State Zip Code
 (328) - 264-2851
 Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____
 STATE WELL PERMIT #(if applicable) _____
 DWQ or OTHER PERMIT #(if applicable) _____
 WELL USE (Check Applicable Box): Residential Water Supply
 DATE DRILLED 2/21/2008
 TIME COMPLETED 2:00 AM PM

3. WELL LOCATION:

CITY: BLOWING ROCK COUNTY: WATAUGA
LOT # 15R IN FRIENDLY MTN. ACRES OFF TONI R
 (Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
 (check appropriate box)
 LATITUDE 3 30 10871
 LONGITUDE 081 30514
 Latitude/longitude source: GPS Topographic map
 (location of well must be shown on a USGS topo map and attached to this form if not using GPS)

May be in degrees, minutes, seconds or in a decimal format

5. WELL DETAILS:

a. TOTAL DEPTH: 425
 b. DOES WELL REPLACE EXISTING WELL? YES NO
 c. WATER LEVEL Below Top of Casing: 100 FT.
 (Use "+" if Above Top of Casing)
 d. TOP OF CASING IS 1 FT. Above Land Surface*
 * Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118
 e. YIELD (gpm): 50 METHOD OF TEST Air

f. DISINFECTION: Type MTH Amount 87

g. WATER ZONES (depth):
 From 25 To 205 From 300 To 320
 From _____ To _____ From _____ To _____
 From _____ To _____ From _____ To _____

6. CASING: Thickness/
 Depth Diameter Weight Material
 From 0 To 200 Ft. 8 1/4 158 GALV
 From 0 To 0 Ft. _____ _____
 From _____ To _____ Ft. _____ _____

7. GROUT: Depth Material Method
 From 0 To 70 Ft. Cement Gravity Flow
 From _____ To _____ Ft. _____ _____
 From _____ To _____ Ft. _____ _____

8. SCREEN: Depth Diameter Slot Size Material
 From _____ To _____ Ft. _____ in. _____ in. _____
 From _____ To _____ Ft. _____ in. _____ in. _____
 From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK: Size Material
 Depth
 From _____ To _____ Ft. _____
 From _____ To _____ Ft. _____
 From _____ To _____ Ft. _____

10. DRILLING LOG

From	To	Formation Description
<u>0</u>	<u>195</u>	<u>DIRT</u>
<u>195</u>	<u>205</u>	<u>GRANITE</u>
<u>205</u>	<u>208</u>	<u>SHALE</u>
<u>208</u>	<u>209</u>	<u>GRANITE</u>
<u>209</u>	<u>220</u>	<u>SHALE</u>
<u>220</u>	<u>425</u>	<u>GRANITE</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

11. REMARKS:

25 GPM 205 - 208 25 GPM 300 - 320
0 GPM - 0 GPM -
0 GPM - 0 GPM -
 I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS; AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 3-23-08
 SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE
STEVE REECE
 PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center - Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.