



RESIDENTIAL WELL CONSTRUCTION RECORD

WS

825797

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2697 060145

1. WELL CONTRACTOR:

STEVE REECE

Well Contractor (Individual Name)

DEWEY WRIGHT WELL & PUMP CO., INC.

Well Contractor Company Name

STREET ADDRESS P. O. BOX 308

BOONE NC 28607

City or Town State Zip Code

(828) - 284-2651
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) _____

STATE WELL PERMIT #(if applicable) _____

DWQ or OTHER PERMIT #(if applicable) _____

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 4/4/2006

TIME COMPLETED 6:00 AM PM

3. WELL LOCATION:

CITY: BOONE COUNTY: WATAUGA

LOT # 26 IN SPICE BRCH OFF ALDRIDGE RD. OFF

(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

Slope Valley Flat Ridge Other
(check appropriate box)

LATITUDE 3 38.07800

LONGITUDE 08147399

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: GPS Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

5. WELL DETAILS:

a. TOTAL DEPTH: 485

b. DOES WELL REPLACE EXISTING WELL? YES NO

c. WATER LEVEL Below Top of Casing: 40 FT.
(Use "+" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
* Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118

e. YIELD (gpm): 30 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 81

g. WATER ZONES (depth):

From 50 To 53 From 450 To 453

From _____ To _____ From _____ To _____

From _____ To _____ From _____ To _____

6. CASING:

Thickness/

From 0 To 39 Ft. 8 1/8 Weight 350 Material PVC

From 0 To 0 Ft. _____

From _____ To _____ Ft. _____

7. GROUT:

Depth Material Method

From 0 To 20 Ft. Cement Gravity Flow

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

8. SCREEN:

Depth Diameter Slot Size Material

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

From _____ To _____ Ft. _____ in. _____ in. _____

9. SAND/GRAVEL PACK:

Depth Size Material

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

From _____ To _____ Ft. _____

10. DRILLING LOG

From To Formation Description

0 33 DIRT

33 50 GRANITE

50 53 SHALE

53 450 GRANITE

450 453 QUARTZ

453 485 GRANITE

11. REMARKS:

1 GPM 50 - 53 28 GPM 450 - 453

0 GPM - 0 GPM -

0 GPM - 0 GPM -

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Steve Reece 4-18-06

SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

STEVE REECE

PRINTED NAME OF PERSON CONSTRUCTING THE WELL

REC'D BY DIVISION, DATE APR 27 2006